



NOTES:

- New detached one- and two-family dwellings, and multiple single-family dwellings (townhouses) with not less than 600 square feet of roof area oriented between 110 degrees and 270 degrees of true north shall have a SOLAR-READY ZONE that complies with the requirements of Appendix U of the Code.
- Capped roof penetration sleeve, provided adjacent to solar-ready zone, shall be sized to accommodate the future photovoltaic system cables, but shall have an inside diameter not less than 1 1/4 inches.
- The main electrical service panel shall have a reserved space to allow installation of a dual pole circuit breaker for future solar electric installation and shall be labeled "For Future Solar Electric."



STANDARD DRAWING
 BUILDING CODE ENFORCEMENT
 CACD

SINGLE FAMILY RESIDENCE
 SOLAR READY EXAMPLE
 1002 WASHINGTON AVE, HOUSTON, TX 77002

APPROVED BY: *[Signature]*
 BUILDING OFFICIAL
 DATE: 4-22-25 DWG NO: 25-15-R 1/1