



**TYPICAL CROSS-SECTION**

**NOTES:**

1. WHERE MULTIPLE BOX SEWER ARE USED IN THE SAME TRENCH, MIN OUTSIDE TO OUTSIDE BOX SEWER SEPARATION SHALL BE 6".
2. REFER TO COH STANDARD DETAILS 02951-01 THROUGH 05 FOR STREET CUT REQUIREMENTS.

*DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE TEXAS ENGINEERING PRACTICE ACT. THE DESIGN REQUIREMENTS ON THIS STANDARD DO NOT PURPORT TO ADDRESS ALL OF THE SAFETY CONCERNS ASSOCIATED WITH THEIR USE. THE ENGINEER OF RECORD (EOR) IS TO REVIEW THESE DESIGN REQUIREMENTS AND BY AUTHORIZING THEIR USE, ACCEPTS RESPONSIBILITY FOR THEIR APPLICABILITY, ADEQUACY AND SAFETY. NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF HOUSTON FOR ANY PURPOSES WHATSOEVER. THE CITY OF HOUSTON ASSUMES NO RESPONSIBILITY FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.*

**CITY OF HOUSTON**  
HOUSTON PUBLIC WORKS STANDARD

**PRECAST CONCRETE BOX STORM SEWER BEDDING AND BACKFILL FOR DRY STABLE TRENCH**

(SCALE: NOT TO SCALE)

APPROVED BY:

Signed by:   
1BE8B22072F84DC...  
CITY ENGINEER

Signed by:   
BE463EF0DF454EB...  
DIRECTOR OF HPW

EFF DATE: MAR-02-2026 | DWG NO: 02317-05