


- NOTES:
- CRITICALLY LOCATE EXISTING BENDS/JOINTS ON 42" WATER LINE PRIOR TO SUBMITTAL OF LAY SCHEDULE. PLACE TS&V MINIMUM 5 FEET AWAY FROM CURRENT BEND/JOINT. SHIFT TS&V UPON APPROVAL BY PROJECT MANAGER. CONTRACTOR TO SET THE MASTER PRV VAULT LOCATION AFTER SETTING THE WATER LINE. AT GRADE ACCESS POINT AND MAGNESIUM GROUND ROD TO BE PLACED MINIMUM 1.5' CLEAR OF EXISTING UTILITIES.


ASPHALT REPLACEMENT TABLE

POINT	STATION AND OFFSET	ELEVATION
A	11+64.18, 12.02' LT	39.84
B	11+87.09, 4.26' LT	39.83
C	11+93.21, 14.41' RT	39.12
D	12+15.43, 17.50' RT	39.98
E	13+16.52, 18.74' RT	40.88
F	13+80.96, 20.99' RT	40.68
G	14+07.53, 25.14' RT	40.60
H	11+55.54, 33.28' RT	38.05
I	12+14.98, 33.66' RT	39.83
J	13+16.76, 35.40' RT	40.52
K	13+79.98, 36.03' RT	40.36
L	13+95.52, 42.03' RT	40.09



EXAMPLE PLAN AND PROFILE NOTES

- THIS EXAMPLE P&P IS PROVIDED FOR GENERAL GUIDANCE AND IS NOT INTENDED TO REFLECT ALL GRAPHIC REQUIREMENTS.
- FOR DRAWING GRAPHIC REQUIREMENTS, REFER TO HOUSTON PUBLIC WORKS INFRASTRUCTURE DESIGN MANUAL.



DESIGN ENGINEER NAME \_\_\_\_\_


ADDRESS \_\_\_\_\_

TELEPHONE NUMBER \_\_\_\_\_

TX FIRM NUMBER \_\_\_\_\_

SURVEYED BY: \_\_\_\_\_

FB NO. 000000



CITY OF HOUSTON  
HOUSTON PUBLIC WORKS

EXAMPLE  
PLAN & PROFILE

WBS NUMBER	FOR CITY OF HOUSTON USE ONLY
X-000X00-0000-X	
DRAWING SCALE	
AS NOTED	
CITY OF HOUSTON PM	
JOHN DOE, P.E.	
SHEET NO. XX OF XX	

PLOTTED: XX/XX/XXXX XX:XX AM  
 PLOT STYLE: XXX.ctb  
 FILE PATH: C:\example\directory\exampleppp.dwg