


2x4 wood studs 24" o.c. with $\frac{5}{8}$ " Type X gypsum board nailed to each side with 6d cooler or wall board nails @ 7" o.c.

OR

2x4 wood studs 16" o.c. with $\frac{5}{8}$ " Type X gypsum board applied to each side with 1 $\frac{1}{4}$ " Type W drywall screws 12" o.c.

- 2012 IBC Table 721.1(2), Item number 14-1.3
 -GA-216-2007 File number WP 3514 & WP 3520

NOTE: For combustible construction



STANDARD DRAWING
CITY OF HOUSTON
 DEPARTMENT OF PUBLIC
 WORKS & ENGINEERING

INTERIOR WOOD PARTITION
 (FIRE RATED - 1 HR)
 1002 WASHINGTON AVE., HOUSTON, TEXAS 77002

APPROVED BY:
[Signature]
 BUILDING OFFICIAL
 DATE: 5/30/2018 DWG No: 18-07-M 1 of 1