


CODE REFERENCE:

R501.3 Fire protection of floors. Floor assemblies that are not required elsewhere in this code to be fire-resistance rated, shall be provided with a $\frac{1}{2}$ inch gypsum wall-board membrane, $\frac{5}{8}$ inch wood structural panel membrane, or equivalent on the underside of floor framing member.

* This detail does not address, and is not applicable to fire resistance ratings for exterior walls and projections that are required due to location on property and related fire separation distance.



STANDARD DRAWING

CITY OF HOUSTON
HOUSTON PUBLIC WORKS

**RESIDENTIAL FIRE PROTECTION
OF NON FIRE-RESISTANCE
RATED FLOOR ASSEMBLIES**

1002 WASHINGTON AVE., HOUSTON, TEXAS 77002

APPROVED BY: *MGN*

BUILDING OFFICIAL

DATE:
9/16/2021

DWG No:
21-02-R

1 of 1