


NOTES:

- New detached one- and two-family dwellings, and multiple single-family dwellings (townhouses) with not less than 600 square feet of roof area oriented between 110 degrees and 270 degrees of true north shall have a SOLAR-READY ZONE that complies with the requirements of Appendix U of the Code.
- Conduit not less than 1 1/4 inches in diameter shall be installed to provide a pathway from the electric panel to the underside of the roof to allow for future installation of solar equipment.
- The main electrical service panel shall have a reserved space to allow installation of a dual pole circuit breaker for future solar electric installation and shall be labeled "For Future Solar Electric."

P.L.



STANDARD DRAWING

CITY OF HOUSTON
HOUSTON PUBLIC WORKS
BUILDING CODE ENFORCEMENT

**SINGLE FAMILY RESIDENCE
SOLAR READY EXAMPLE**

1002 WASHINGTON AVE., HOUSTON, TEXAS 77002

APPROVED BY:

BUILDING OFFICIAL

DATE:
11 / 15 / 2022

DWG No:
22-01-R Rev. 1

1 of 1