

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

CHAPTER 1 SCOPE AND ADMINISTRATION	2021 Proposed	Code Analysis
PART 1—SCOPE AND APPLICATION		
<p align="center">SECTION 101 GENERAL</p> <p>[A] 101.1 Title. These regulations shall be known as the Performance Code of [NAME OF JURISDICTION], hereinafter referred to as “this code.”</p>		
<p>[A] 101.2 Purpose. To provide appropriate health, safety, welfare, and social and economic value, while promoting innovative, flexible and responsive solutions that optimize the expenditure and consumption of resources.</p>		
<p>[A] 101.3 Scope. [A] 101.3.1 Building. Part II of this code provides requirements for buildings and structures and includes provisions for structural strength, stability, sanitation, means of access and egress, light and ventilation, safety to life and protection of property from fire and, in general, to secure life and property from other hazards affecting the built environment. This code includes provisions for the use and occupancy of buildings, structures, facilities and premises, their alteration, repair, maintenance, removal, demolition, and the installation and maintenance of amenities including, but not limited to, such services as the electrical, gas, mechanical, plumbing, energy conservation and building transportation systems.</p>		
<p>[A] 101.3.2 Fire. Part III of this code establishes requirements applicable to the use and occupancy of buildings, structures and facilities; and to the prevention, control and mitigation of fire, life safety and property hazards arising from this use and from the storage, handling and use of explosive, flammable and combustible materials, hazardous materials and dangerous operations and processes.</p>		
<p>[A] 101.4 Intent. [A] 101.4.1 Building. The purpose of this code is to provide an acceptable level of health, safety, and general welfare and to limit damage to property from events that are expected to impact buildings and structures. Accordingly, Part II of this code intends buildings and structures to provide for the following:</p> <ol style="list-style-type: none"> 1. An environment free of unreasonable risk of death and injury from fires. 2. A structure that will withstand loads associated with normal use and of the severity associated with the location in which the structure is constructed. 3. Means of egress and access for normal and emergency circumstances. 4. Limited spread of fire both within the building and to adjacent properties. 5. Ventilation and sanitation facilities to maintain the health of the occupants. 6. Natural light, heating, cooking and other amenities necessary for the well being of the occupants. 7. Efficient use of energy. 8. Safety to fire fighters and emergency responders during emergency operations. 		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[A] 101.4.2 Fire. Part III of this code establishes requirements necessary to provide a reasonable level of life safety and property from the hazards of fire, explosion or dangerous conditions in facilities, equipment and processes.</p>		
<p style="text-align: center;">PART 2—ADMINISTRATION AND ENFORCEMENT SECTION 102 ADMINISTRATIVE PROVISIONS</p> <p>[A] 102.1 Objective. To achieve and maintain the level of safety intended by the code.</p>		
<p>[A] 102.2 Functional statements. [A] 102.2.1 Qualifications. Registered design professionals shall possess the knowledge, skills and abilities necessary to demonstrate compliance with this code.</p>		
<p>[A] 102.2.2 Construction document preparation. Construction documents required by this code shall be prepared in adequate detail and submitted for review and approval.</p>		
<p>[A] 102.2.3 Review. Construction documents submitted in accordance with this code shall be reviewed for code compliance with the appropriate code provisions.</p>		
<p>[A] 102.2.4 Construction. Construction shall comply with approved construction documents submitted in accordance with this code, and shall be verified and approved to demonstrate compliance with this code.</p>		
<p>[A] 102.2.5 Facilities and premises. Facilities and premises shall comply with approved design construction documents submitted in accordance with this code, and shall be verified and approved to demonstrate compliance with this code.</p>		
<p>[A] 102.2.6 Equipment and processes. Equipment and processes and their installation and operation shall comply with approved construction documents submitted in accordance with this code, and shall be verified and approved to demonstrate compliance with this code.</p>		
<p>[A] 102.2.7 Materials and contents. Materials and contents shall comply with approved construction documents submitted in accordance with this code, and shall be verified and approved to demonstrate compliance with this code.</p>		
<p>[A] 102.2.8 Facility operating policies and procedures. Policies, operations, training and procedures shall comply with approved documents submitted in accordance with this code, and shall be verified and approved to demonstrate compliance with this code.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[A] 102.2.9 Supplemental enforcement. Administrative provisions of the International Code Council's family of codes regarding plan review, permit issue, inspection and enforcement shall supplement these provisions.</p>		
<p>[A] 102.2.10 Maintenance. Maintenance of the performance-based design shall be ensured through the issuance and renewal of certificates over the life of the building.</p>		
<p>[A] 102.2.11 Management of change. Written procedures managing change to original construction documents, system processes, technology, equipment and facilities shall be established and implemented.</p>		
<p>[A] 102.2.12 Expected emergency response. Construction documents shall clearly describe the level of response expected by emergency responders.</p>		
<p>[A] 102.3 Performance requirements. [A] 102.3.1 Building owner's, or the owner's authorized agent's, responsibility. [A] 102.3.1.1 Registered design professional. The owner or the owner's authorized agent shall have the responsibility of retaining and furnishing the services of a registered design professional, who shall be in responsible charge of preparing and coordinating a complete and comprehensive set of construction documents and other services required to prepare reports and other documents in accordance with this code. If the services required by this section are not provided, the use of this code is prohibited.</p>		
<p>[A] 102.3.1.2 Registered design professional in responsible charge. Where the project requires the services of multiple registered design professionals, a registered design professional in responsible charge shall be retained and furnished who shall have the contractual responsibility and authority over all required registered design professional disciplines to prepare and coordinate a complete and comprehensive set of construction documents for the project.</p>		
<p>[A] 102.3.1.3 Peer review. The owner or the owner's authorized agent shall be responsible for retaining and furnishing the services of a registered design professional or recognized expert, who will perform as a peer reviewer, where required and approved by the code official. See Section 102.3.6.3 of this code.</p>		
<p>[A] 102.3.1.4 Costs. The costs of special services, including contract review, where required by the code official, shall be borne by the owner or the owner's authorized agent.</p>		
<p>[A] 102.3.1.5 Document retention. The owner or the owner's authorized agent shall retain on the premises documents and reports required by this code and make them available to the code official upon request.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.1.6 Maintenance. The owner or the owner’s authorized agent is responsible to operate and maintain a building, structure or facility designed and built under this code in accordance with the bounding conditions and the operations and maintenance manual.</p>		
<p>[A] 102.3.1.7 Changes. The owner or the owner’s authorized agent shall be responsible to ensure that any change to the facility, process or system does not increase the hazard level beyond that originally designed without approval and that changes shall be documented in accordance with this code.</p>		
<p>[A] 102.3.1.8 Special expert. Where the scope of work is limited or focused in an area that does not require the services of a registered design professional or the special knowledge and skills associated with the practice of architecture or engineering, a special expert may be employed by the owner or the owner’s authorized agent as the person in responsible charge of the limited or focused activity. It is the intent of this code that the individual shall possess the qualification characteristics required in Appendix D.</p>		
<p>[A] 102.3.1.9 Occupant requirements. The owner or the owner’s authorized agent is responsible and accountable to ensure that occupants and employees who are required to take certain actions or perform certain functions in accordance with a performance-based design possess the required knowledge and skills and are empowered to perform those actions.</p>		
<p>[A] 102.3.2 Registered design professional qualifications. The registered design professional in responsible charge, architects, engineers and other registered design professionals in responsible charge of their discipline as a member of a design team shall be responsible and accountable to possess the required knowledge and skills to perform design, analysis and verification in accordance with the provisions of this code and applicable professional standards of practice. It is the intent of this code that these individuals possess the qualification characteristics as stated in Appendix D. Qualification statements shall be submitted to the code official for the registered design professional in responsible charge, registered design professionals and special experts to demonstrate compliance with Appendix D.</p>		
<p>[A] 102.3.3 Registered design professionals’ and special experts’ responsibilities. [A] 102.3.3.1 Registered design professional in responsible charge. Where multiple design disciplines are involved, the registered design professional in responsible charge is responsible to ensure that design elements are comprehensive and complete before submittals are made to the code official. During the code review process all designated reports, drawings and construction documents necessary to demonstrate compliance with the code shall be submitted by the registered design professional in responsible charge. The responsibilities of the registered design professional in responsible charge include those of a registered design professional.</p>		
<p>[A] 102.3.3.2 Responsibilities. Registered design professionals are responsible to apply the performance requirements and acceptable methods approach in Section 103.3 for performance-based designs where using this code. This code requires design analysis and support documentation to demonstrate the design approach and to verify design objectives and compliance with this code.</p>		
<p>[A] 102.3.3.3 Supporting documentation. Registered design professionals have the responsibility to provide the appropriate design analysis, research, computations and documentation to demonstrate compliance with applicable performance requirements of this code and applicable prescriptive code provisions.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.3.4 Acceptable methods. Registered design professionals shall use authoritative documents or design guides to determine testing and verification methods for selecting building materials that are compatible with the building systems approach selected.</p>		
<p>[A] 102.3.3.5 References. Registered design professionals are responsible to document applicable design guides or authoritative documents for a performance-based design and demonstrate how these documents are utilized to substantiate design solutions to show compliance with the provisions of this code. The use of documents that are not accepted as authoritative documents or design guides requires substantiation with the code official to obtain acceptance.</p>		
<p>[A] 102.3.3.6 Documentation of bounding conditions. The registered design professional shall document all bounding conditions and establish thresholds that determine when changes must be approved by the code official.</p>		
<p>[A] 102.3.3.7 Compliance with bounding conditions. The registered design professional shall review the completed construction elements, equipment, furnishings, processes and contents to verify compliance with the bounding conditions and the critical design features identified in the approved construction documents. The code official may require that the registered design professional in responsible charge file a report to verify compliance with the bounding conditions and the critical design features at the completion of the project as a condition of obtaining required certificates.</p>		
<p>[A] 102.3.3.8 Special expert. The scope of work of a special expert shall be limited to the area of expertise as demonstrated in the documentation submitted to the code official for review and approval. Where a special expert performs functions of a design, the special expert shall assume the responsibilities of that phase of the design.</p>		
<p>[A] 102.3.4 Design documentation. [A] 102.3.4.1 General. The registered design professional shall prepare appropriate documentation for the project that clearly provides the design approach and rationale for design submittal, construction and future use of the building, facility or process.</p>		
<p>[A] 102.3.4.1.1 Required documentation. The documentation for the project shall identify the goals and objectives; the steps undertaken in the analytical analysis; the facility maintenance and testing requirements; and limitations and restrictions on the use of the facility in order to stay within bounding conditions. Where requirements for documentation are specified in applicable engineering or design guides, documentation shall be included in the construction documents. Computer modeling documentation shall comply with Appendix E.</p>		
<p>[A] 102.3.4.1.2 Extent of documentation. The level of documentation provided shall be adequate to convey the required information clearly to the involved parties and shall be commensurate with the scope and complexity of the project.</p>		
<p>[A] 102.3.4.1.3 Verification of compliance. Documentation shall be prepared that clearly verifies that applicable performance and applicable prescriptive code provisions have been met.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[A] 102.3.4.1.4 Deed restriction. Design features with bounding conditions that require continued maintenance or supervision by the owner or the owner's authorized agent throughout the life of the building, facility or process as conditions of compliance with the objectives of this code shall be recorded as a deed restriction until released by the code official. Where required by the code official, the deed restriction shall be modified to reflect specific changes.</p>		
<p>[A] 102.3.4.1.5 Phased and partial occupancy. The construction documents shall include an evaluation of hazards and proposed resolution of associated risks during construction in advance of a request for phased or partial occupancy.</p>		
<p>102.3.4.1.6 Emergency response capabilities. Design documentation shall clearly describe the level of response expected by emergency responders under the direct control of the owner or the owner's authorized agent. Emergency response capabilities, staffing levels, training requirements and equipment availability shall be documented as a bounding condition.</p>		
<p>[A] 102.3.4.2 Reports and manuals. Where required by the code official, design documentation shall include a concept report, design report and operations and maintenance manual.</p>		
<p>[A] 102.3.4.2.1 Concept report. The concept report shall document the preliminary details of the project, identify the parties involved in the project, and define the goals and objectives to be utilized in the performance-based design analysis. The concept report shall be submitted to the code official as a means of communicating the programming and early schematic phase of a proposed project and to obtain concurrence between the code official and the project design team on the goals and objectives to be utilized in the analysis. The concept report shall address but not be limited to the following:</p> <ol style="list-style-type: none"> 1. General project information, including schematic layout and site plan. 2. Definition of project scope. 3. Description of building and occupant characteristics. 4. Project goals and objectives. 5. Selected event scenarios. 6. Methods of evaluation. 7. Qualification statements for the registered design professional in responsible charge, registered design professionals and special experts. 8. Proposed performance and prescriptive code usage. 9. Conceptual site and building plan. 		
<p>[A] 102.3.4.2.2 Design report. The design report shall document the steps taken in the design analysis, clearly identifying the criteria, parameters, inputs, assumptions, sensitivities and limitations involved in the analysis. The design report shall clearly identify bounding conditions, assumptions and sensitivities that clarify the expected uses and limitations of the performance analysis. This report shall verify that the design approach is in compliance with the applicable codes and acceptable methods and shall be submitted for concurrence by the code official prior to the construction documents being completed. The report shall document the design features to be incorporated based on the analysis. The design report shall address but not be limited to the following:</p> <ol style="list-style-type: none"> 1. Project scope. 2. Goals and objectives. 3. Performance criteria. 		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<ul style="list-style-type: none"> 4. Hazard scenarios. 5. Design fire loads and hazards. 6. Final design. 7. Evaluation. 8. Bounding conditions and critical design assumptions. 9. Critical design features. 10. System design and operational require-ments. 11. Operational and maintenance require-ments. 12. Commissioning testing requirements and acceptance criteria. 13. Frequency of certificate renewal. 14. Supporting documents and references. 15. Preliminary site and floor plans. 		
<p>[A] 102.3.4.2.3 Operations and maintenance manual. The operations and maintenance manual shall identify system and component commissioning requirements and the required interactions between these systems. The manual shall identify for the facility owner or the owner’s authorized agent and the facility operator those actions that need to be performed on a regular basis to ensure that the components of the performance-based design are in place and operating properly. Further-more, the operations and maintenance manual shall identify the restrictions or limitations placed on the use and operation of the facility in order to stay within the bounding conditions of the performance-based design. The operations and maintenance manual shall be submitted at the time of the construction documents submittal, unless the code official approves another time based on the type of project and data needed for a composite review. The operations and maintenance manual shall address but not be limited to the following:</p> <ul style="list-style-type: none"> 1. Description of critical systems. 2. Description of required system inter-actions. 3. Occupant responsibilities. 4. Occupant and staff training requirements. 5. Periodic operational requirements. 6. Periodic maintenance requirements. 7. Periodic testing requirements. 8. Limitations on facility operations (due to bounding conditions). 9. Report format for recording maintenance and operation data. 10. System and component commissioning requirements. 		
<p>[A] 102.3.5 Design submittal. [A] 102.3.5.1 General. Applicable construction documents required in Sections 102.3.2, 102.3.3 and 102.3.4 for submittal in this code and other applicable codes under the jurisdiction of the code official shall be submitted to the code official for review. The documents shall be submitted in accordance with the jurisdiction’s procedures and in sufficient detail to obtain appropriate permits.</p>		
<p>[A] 102.3.5.2 Coordination of construction documents. Design documents shall be coordinated by the registered design professional in responsible charge for consistency, compatibility and completeness prior to submittal. Documentation shall be provided to the code official to demonstrate compliance with the performance provisions, including acceptable methods.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.5.3 Performance-based design features. The construction documents shall clearly indicate those areas of the design that are performance-based and shall be provided to the code official.</p>		
<p>[A] 102.3.5.4 Extent of documentation and references. The code official shall be provided with sufficient documentation to support the validity, accuracy, relevance and precision of the proposed methods. Copies of referenced documentation shall be made available to the code official.</p>		
<p>[A] 102.3.5.5 Inspections, testing, operation and maintenance. The construction documents shall specify when and where special inspection and testing are required, the standards of acceptance for demonstrating compliance with the construction documents, and operations and maintenance requirements for future use of the building.</p>		
<p>[A] 102.3.5.6 Management of change. The submittal shall include appropriate management of change protocol to address how changes in the construction documents will be managed for construction, operation and maintenance activities.</p>		
<p>[A] 102.3.6 Review and approval. [A] 102.3.6.1 Procedures. Document review and approval shall be accomplished in accordance with the code official's procedures.</p>		
<p>[A] 102.3.6.2 Review. The code official shall be responsible to perform a knowledgeable review of the proposed design project to verify compliance with this code, or the code official shall retain competent assistance to perform the review in accordance with acceptable standards of practice.</p>		
<p>[A] 102.3.6.3 Contract and peer review. Review may be accomplished by a contract reviewer where the reviewer is assigned by the code official. In addition, the code official may require a peer review process to review design criteria and supporting documents and construction documents.</p>		
<p>[A] 102.3.6.4 Approval. After documents and other supporting data are reviewed and approved by the code official to verify compliance with the applicable codes, permits may be issued.</p>		
<p>[A] 102.3.7 Permits and inspections. [A] 102.3.7.1 Permits. Prior to the start of construction, appropriate permits shall be obtained in accordance with the jurisdiction's procedures and applicable codes.</p>		
<p>[A] 102.3.7.2 Inspection. Approved inspections shall be obtained in accordance with the construction documents, jurisdiction's procedures and applicable codes.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.7.3 Verification reports. Inspection, testing and related verification reports shall be filed with the code official to verify compliance with approved construction documents and applicable prescriptive code provisions.</p>		
<p>[A] 102.3.7.4 Product installation. Compliance shall be verified for materials, fabrication, manufacturer’s and engineer’s installation procedures by product labeling, certification, quality assurance processes and testing, as applicable, to verify compliance.</p>		
<p>[A] 102.3.7.5 Compliance verification. At the completion of construction, the code official shall verify that inspection and testing reports demonstrate compliance with the applicable codes and approved construction documents.</p>		
<p>[A] 102.3.7.6 Operational permits. Prior to initiating facility uses and processes regulated under Part III of this code, appropriate permits shall be obtained.</p>		
<p>[A] 102.3.8 Project documentation. [A] 102.3.8.1 Verification of compliance. Upon completion of the project, documentation shall be prepared that verifies performance and prescriptive code provisions have been met. Where required by the code official in accordance with Section 102.3.3.6, the registered design professional in responsible charge shall file a report that verifies bounding conditions are met.</p>		
<p>[A] 102.3.8.2 Extent of documentation. Approved construction documents, the operations and maintenance manual, inspection and testing records, and certificates of occupancy with conditions shall be included in the project documentation of the code official’s records.</p>		
<p>[A] 102.3.8.3 Deed restrictions. Design features with bounding conditions determined by the registered design professional to require continued operation and maintenance by the owner or the owner’s authorized agent throughout the life of the building as conditions of compliance with the objectives of this code shall be recorded as a deed restriction as required by the code official until released by the code official</p>		
<p>[A] 102.3.8.4 Technical opinion. The code official has the authority to require a technical opinion and report from an individual or organization with special expertise to identify and develop methods of protection from special hazards and to determine the acceptability of technologies, processes, products, equipment, materials and uses applicable to the design, operation or use of a building or facility. The intent of this code is that the technical opinion and report shall be prepared by a qualified individual. See Appendix D.</p>		
<p>[A] 102.3.9 Certificates. [A] 102.3.9.1 Certificate of occupancy. Prior to occupancy of a building, a certificate of occupancy shall be obtained from the code official.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.9.1.1 Continued occupancy. A certificate of occupancy is required for the continued occupancy of a building.</p>		
<p>[A] 102.3.9.1.2 Temporary certificate of occupancy. The code official has the authority to issue a temporary certificate of occupancy for a limited time with specified conditions, providing all life-safety items are accepted.</p>		
<p>[A] 102.3.9.1.3 Conditional certificate of occupancy. The code official has the authority to issue a certificate of occupancy with conditions valid for a specified time period that requires continued compliance with bounding conditions and the operations and maintenance manual. Failure to maintain compliance with the conditions of the certificate of occupancy is a violation of this code.</p>		
<p>[A] 102.3.9.1.4 Revocation and renewal. Failure of the building owner or the owner's authorized agent to demonstrate to the code official that the building is being operated and maintained in compliance with Sections 102.3.1.6 and 102.3.9.1 is cause to revoke or not renew a certificate of occupancy.</p>		
<p>[A] 102.3.9.2 Certificate of compliance. Prior to use of a building, facility, process or premises subject to Part III of this code, a certificate of compliance shall be obtained from the code official.</p>		
<p>A] 102.3.9.2.1 Continued use. A certificate of compliance is required for the continued use or occupancy of a facility, process or equipment subject to Part III of this code throughout the life of the facility.</p>		
<p>[A] 102.3.9.2.2 Renewal frequency. The certificate of compliance issued subject to Part III of this code shall be renewed at a frequency as determined in the design and approved by the code official.</p>		
<p>[A] 102.3.9.2.3 Revocation and renewal. Failure of the owner or the owner's authorized agent to demonstrate compliance with this section is cause to revoke or not renew the certificate of compliance.</p>		
<p>[A] 102.3.10 Maintenance. [A] 102.3.10.1 Owner, or the owner's authorized agent's, responsibility. The owner or the owner's authorized agent is responsible for maintaining the building or facility in accordance with the approved documents.</p>		
<p>[A] 102.3.10.2 Continued compliance. Compliance with the operations and maintenance manual and bounding conditions shall be verified throughout the life of the building or facility at a frequency in accordance with the approved documents.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.10.3 Compliance verification. Documents verifying that the building, facilities, premises, processes and contents are in compliance with the approved construction documents and are maintained in a safe manner shall be filed with the code official at a frequency approved by the code official.</p>		
<p>[A] 102.3.11 Remodeling, addition or change/approval of use. [A] 102.3.11.1 Analysis of change. The registered design professional shall evaluate the existing building, facilities, premises, processes, contents and the applicable documentation of the proposed change as it affects portions of the building, facility, premises, processes and contents that were previously designed for compliance under a performance-based code. Prior to any change that was not documented in a previously approved design, the registered design professional in responsible charge shall examine the applicable design documents, bounding conditions, operation and maintenance manuals, and deed restrictions.</p>		
<p>[A] 102.3.11.2 Coordination of design. Where multiple design disciplines are involved, one registered design professional shall be responsible to ensure that design elements are comprehensive and complete before submittals are made to the code official. During the code review process, designated reports, drawings and construction documents necessary to demonstrate compliance with the code shall be submitted by the registered design professional.</p>		
<p>[A] 102.3.11.3 Change in activity or contents. Any change in activity or contents that results in an increase in hazard or risk that exceeds the bounding conditions requires an evaluation and approval. The code official shall have the authority to require a full evaluation of the design.</p>		
<p>[A] 102.3.11.4 Additions, renovations and related construction changes. Construction activities in existing buildings, facilities, premises or processes shall be evaluated by a registered design professional and documented in a written report, which shall be submitted for review and approval in conjunction with the permit request. The report shall identify whether the proposed construction exceeds the bounding conditions, which will result in an increase in hazard or risk beyond that expected in the approved original construction document. Where bounding conditions are not exceeded, the original construction document need not be revised. Where bounding conditions are exceeded, the original construction document shall be revised so that compliance with this code is perpetuated.</p>		
<p>[A] 102.3.11.5 Designs exceeding bounding conditions. Where a proposed change exceeds the bounding conditions and does not result in an increase to hazard or risk, as approved by the code official, any person authorized by the laws of the jurisdiction is allowed to prepare construction documents and reports for submittal.</p>		
<p>[A] 102.3.11.6 Change in design objectives and bounding conditions. Where changes are proposed to the design objectives and bounding conditions of an existing building, facility, process or contents, a written report by the registered design professional shall be prepared to specify the new design objectives and demonstrate compliance with the current code.</p>		
<p>[A] 102.3.12 Administration and enforcement. [A] 102.3.12.1 Supplemental administrative provisions. Administrative provisions of the International Code Council's family of codes shall supplement the performance provisions for plan review, permit issuance, inspection, certificate of occupancy or compliance, and enforcement.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] 102.3.13 Violations. [A] 102.3.13.1 Unlawful acts. It shall be unlawful for any person, firm or corporation to erect, construct, alter, extend, repair, move, remove, demolish or occupy any building, structure or facility regulated by this code, or cause same to be done, in conflict with or in violation of any of the provisions of this code.</p>		
<p>[A] 102.3.13.2 Notice of violation. The code official shall serve a notice of violation or order on the person responsible for the erection, construction, alteration, extension, repair, moving, removal, demolition or occupancy of a building or facility in violation of the provisions of this code or in violation of a detail statement or construction documents approved thereunder, or in violation of a permit or certificate issued under the provisions of this code. Such order shall direct the discontinuance of the illegal action or condition and the abatement of the violation.</p>		
<p>[A] 102.3.13.3 Violation. If the notice of violation is not complied with promptly, the code official has the authority to request the legal counsel of the jurisdiction to institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of the unlawful occupancy of the building or structure in violation of the provisions of this code or of the order or direction made pursuant thereto.</p>		
<p>[A] 102.3.13.4 Penalties. Any person who violates a provision of this code or fails to comply with any of the requirements thereof or who erects, constructs, alters or repairs a building, structure or facility in violation of the approved construction documents or directive of the code official or of a permit or certificate issued under the provisions of this code shall be subject to penalties as prescribed by law.</p>		
<p style="text-align: center;">SECTION 103 ACCEPTABLE METHODS</p> <p>[A] 103.1 Objective. To require the use of recognized authoritative documents or design guides for analysis, measurement of performance and determination of criteria used to evaluate compliance with the performance requirements of this code. See Chapter 2 for definitions.</p>		
<p>[A] 103.2 Functional statements. [A] 103.2.1 Approved methodologies. Design approaches shall utilize authoritative documents and design guides to demonstrate that designs are based on applicable and valid technical and scientific methodologies.</p>		
<p>[A] 103.2.2 Construction documents. Construction documents shall indicate the method by which the design and construction are to be verified and applicable systems are to be measured.</p>		
<p>[A] 103.2.3 Testing and inspection. Testing and inspection of materials and systems shall be based on applicable authoritative documents and design guides.</p>		
<p>[A] 103.3 Performance requirements and acceptance method approach. [A] 103.3.1 Construction documents. Registered design professionals shall utilize acceptable methods. Construction documents shall contain the design approach, analysis, research, computation and criteria for acceptance that specify the applicable design guides, and authoritative documents utilized to demonstrate that design objectives are met.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[A] 103.3.2 Construction documents. Construction documents shall include design verification methods that are required to demonstrate compliance with design objectives and applicable authoritative documents and design guides.</p>		
<p>[A] 103.3.3 Individually substantiated design methods. Documents that do not meet the criteria for authoritative documents or design guides shall comply with the individually substantiated design method criteria in Appendix C.</p>		
<p>[A] 103.3.4 Peer review. Designs that propose to use documents that do not meet the criteria for authoritative documents or design guides shall not be permitted unless approval is given by the code official. The resulting performance-based design shall undergo an independent peer review process.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 2 DEFINITIONS	2021 Proposed	Code Analysis
<p align="center">SECTION 201 GENERAL</p> <p>[BG] 201.1 Scope. Unless otherwise expressly stated, the following words and terms shall, for the purposes of this code, have the meanings indicated in this chapter.</p>		
<p>[BG] 201.1 Scope. Unless otherwise expressly stated, the following words and terms shall, for the purposes of this code, have the meanings indicated in this chapter.</p>		
<p>[BG] 201.2 Interchangeability. Words used in the present tense include the future; words in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.</p>		
<p>[BG] 201.3 Terms not defined in other codes. Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies.</p>		
<p align="center">SECTION 202 DEFINED TERMS</p> <p>[A] ACCEPTABLE METHODS. Design, analysis and testing methods that have been approved for use in developing design solutions for compliance with the requirements of this code. See Section 103.</p>		
<p>[BG] AMENITY. [BG] AMENITY. An attribute of, or system in, the building that provides services or functions related to the use of the building by the occupants or that contributes to the comfort of the occupants, and that is not necessary for the minimum protection of the occupants. For example, an automatic sprinkler system is not a building amenity.</p>		
<p>[A] ARCHITECT/ENGINEER. The individual architect or engineer who is registered or licensed to practice his or her respective design profession as defined by the statutory requirements of the professional registration laws of the state or jurisdiction in which the project is to be constructed. See Qualification Characteristics in Appendix D.</p>		
<p>[A] AUTHORITATIVE DOCUMENT. A document containing a body of knowledge commonly used by practicing architects or engineers. It represents the state of the art, including accepted engineering practices, test methods, criteria, loads, safety factors, reliability factors and similar technical matters. The document portrays the standard of care normally observed with a particular discipline. The content is promulgated through an open consensus process or a review by professional peers conducted by recognized authoritative professional societies, codes or standards organizations, or governmental bodies.</p>		
<p>[A] BOUNDING CONDITIONS. Conditions that, if exceeded, invalidate the performance-based design. These could be maximum allowable conditions such as fuel load or type and arrangement of fuel load that must be maintained throughout the life of a building to ensure that design parameters are not exceeded.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[A] CODE. The term used in this document to refer to the International Code Council Performance Code for Buildings and Facilities. Other codes in the International Code Council’s family of codes and the National Electrical Code are identified where used.</p>		
<p>[A] COMMISSIONING. The process of verifying that a system meets design, technical standards and code expectations via inspection, testing and operational functionality.</p>		
<p>[A] CONSTRUCTION DOCUMENTS. Design drawings and written, graphic and pictorial documents prepared or assembled for describing the design, location and physical characteristics of the elements of a project necessary for obtaining a permit.</p>		
<p>[A] CONSULTANT. An individual who provides specialized services to an owner, designer, code official or contractor.</p>		
<p>[A] CONTRACT REVIEW. Plan review, as defined below, performed by a consultant who is retained by the code official for that purpose.</p>		
<p>[A] DESIGN GUIDE. A document containing a body of knowledge or information used by practicing architects and engineers that is not required to meet an open consensus requirement. It represents accepted architectural/engineering principles and practices, tests and test data, criteria, loads, safety factors, reliability factors and similar technical data.</p>		
<p>[BS] ESSENTIAL FACILITIES. Buildings and other structures that are intended to remain operational in the event of extreme environmental loading from flood, wind, snow or earthquake.</p>		
<p>[A] FACILITY. (General Application) Includes all buildings or structures (permanent or temporary), including all fire- and life-safety systems installed therein. A facility includes interior and exterior storage areas, equipment and processes dealing with flammable and combustible substances and hazardous materials, on site. The term includes tents, membrane structures, mobile and manufactured structures, storage tanks, piers, wharves and all required access roads and areas.</p>		
<p>FACILITY. (Only applicable to Section 702). The entire building or any portion of a building, structure or area, including the site on which such building, structure or area is located, wherein specific services are provided or activities are performed.</p>		
<p>[A] PEER REVIEW. An independent and objective technical review of the design of a building or structure to examine the proposed conceptual and analytical concepts, objectives and criteria of the design and construction. It shall be conducted by an architect or engineer who has a level of experience in the design of projects similar to the one being reviewed at least comparable to that of the architect or engineer responsible for the project.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[A] PERFORMANCE-BASED DESIGN. An engineering approach to design elements of a building based on agreed upon performance goals and objectives, engineering analysis and quantitative assessment of alternatives against the design goals and objectives using accepted engineering tools, methodologies and performance criteria.</p>		
<p>[A] PLAN REVIEW. A review of the construction documents by the code official to verify conformance to applicable performance and prescriptive code requirements.</p>		
<p>[A] PRESCRIPTIVE CODES. The International Code Council’s family of codes, which provide specific (design, construction and maintenance) requirements for building, energy conservation, fire prevention, mechanical, plumbing and so forth.</p>		
<p>[A] QUALITY ASSURANCE. Inspection by code officials, and special inspection and testing by qualified persons and observation by architects/engineers, where applicable, of the construction of a building or structure to verify general conformance with the construction documents, and applicable performance and prescriptive code requirements.</p>		
<p>[A] REGISTERED DESIGN PROFESSIONAL. An individual who is registered or licensed to practice his or her respective design profession as defined by the statutory requirements of the professional registration laws of the state or jurisdiction in which the project is to be constructed.</p>		
<p>[A] REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE. A registered design professional engaged by the owner or the owner’s authorized agent to review and coordinate certain aspects of the project, as determined by the code official, for compatibility with the design of the building or structure, including submittal documents prepared by others, deferred submittal documents and phased submittal documents.</p>		
<p>[BG] SAFE PLACE. An interior or exterior area wherein protection from hazards is provided by construction or appropriate separation distance.</p>		
<p>[BF] SAFETY SYSTEMS. Designed systems in the building provided to serve as the protection for the occupants and the building and contents from hazards.</p>		
<p>[BG] SERIOUS INJURY. An injury requiring hospitalization or multiple visits to a healthcare provider to effect treatment.</p>		
<p>[A] SPECIAL EXPERT. An individual who has demonstrated qualifications in a specific area, outside the practice of architecture or engineering, by education, training and experience.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

[A] THIRD-PARTY REVIEW. A term associated with quality assurance and independence from another party whose work product is being reviewed. Third-party review does not apply to the peer review process.

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 3 DESIGN PERFORMANCE LEVELS	2021 Proposed	Code Analysis
<p align="center">SECTION 301 MINIMUM PERFORMANCE</p> <p>[BG] 301.1 Purpose. This chapter provides the basis for developing the acceptable level of design based on building use, risk factors and magnitudes of event. Magnitudes are defined in subsequent chapters of this code but interrelate with this chapter in the development of design methods for the mitigation of hazards</p>		
<p>[BG] 301.2 Objective. To establish performance groups for buildings and facilities and to establish minimum acceptable losses based on those performance groups.</p>		
<p>[BG] 301.3 Functional statements. [BG] 301.3.1 Performance level. The performance of a building or facility is based on the ability of the building or facility to tolerate specified magnitudes of event within tolerable limits of damage.</p>		
<p>[BG] 301.3.2 Demonstration of performance. Performance is acceptable where the design performance levels are demonstrated to be met or exceeded, to the satisfaction of the code official, in accordance with the assigned or designated use groups, performance groups, magnitudes of event and maximum tolerable damage limits; and the objectives, functional statements and performance requirements of this code.</p>		
<p align="center">SECTION 302 USE AND OCCUPANCY CLASSIFICATION</p> <p>[BG] 302.1 General. The objective of the assignment of use and occupancy classification is to identify the primary uses of buildings and facilities, and portions of buildings and facilities, and to identify risk factors associated with these uses, in order to facilitate design and construction in accordance with other provisions of this code.</p>		
<p>[BG] 302.2 Determination of use. In determining the primary use of a building or facility, or portion of a building or facility, the following shall be considered:</p> <ol style="list-style-type: none"> 1. Principal purpose or function. The principal purpose or function of the building or facility. 2. Hazards. The hazard-related risk(s) to the users of the building or facility. 		
<p>[BG] 302.3 Guidance. The use and occupancy classifications found in the International Building Code shall be permitted to be used for guidance in determining the principal purposes or functions for buildings or facilities.</p>		
<p>[BG] 302.4 Risk factors. In determining the hazard-related risk(s) to users of buildings and facilities, the following risk factors shall be considered:</p>		
<p>[BG] 302.4.1 Nature of the hazard. The nature of the hazard, whether it is likely to originate internal or external to the building or facility, and how it may impact the occupants, the building or facility, and the contents.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 302.4.2 Number of occupants. The number of persons normally occupying, visiting, employed in or otherwise using the building, facility or portion of the building or facility.</p>		
<p>[BG] 302.4.3 Length of occupancy. The length of time the building or facility is normally occupied by people.</p>		
<p>[BG] 302.4.4 Sleeping characteristics. Whether people normally sleep in the building.</p>		
<p>[BG] 302.4.5 Familiarity. Whether the building or facility occupants and other users are expected to be familiar with the building or facility layout and means of egress.</p>		
<p>[BG] 302.4.6 Vulnerability. Whether a significant percentage of the building or facility occupants are, or are expected to be, members of vulnerable population groups such as infants, young children, elderly persons, persons with physical disabilities, persons with mental disabilities, or persons with other conditions or impairments that could affect their ability to make decisions, egress without the physical assistance of others or tolerate adverse conditions.</p>		
<p>[BG] 302.4.7 Relationships. Whether a significant percentage of building or facility occupants and other users have family or dependent relationships.</p>		
<p style="text-align: center;">SECTION 303 PERFORMANCE GROUPS</p> <p>[BG] 303.1 Performance group allocation. Use groups and hazard-related occupancies have been allocated to performance groups using the risk factors identified in Section 302.4. Specific buildings and facilities have been allocated to performance groups using the risk factors identified in Section 302.4 combined with the relative importance of protecting the building or facility to the community. These performance group allocations are shown in Table 303.1.</p>		
<p>[BG] 303.2 Unique performance group allocation. Where necessary or desired, allocation of specific buildings or facilities to performance groups differing from Table 303.1 is permitted based on the needs specific to a community or owner or if there are unusual circumstances associated with the building or facility.</p>		
<p>[BG] 303.3 Magnitudes of event and level of damage. Performance groups identify the minimum required performance of buildings or facilities through a relationship of the magnitude of an event to the maximum level of damage to be tolerated shown in Table 303.3. The use of Table 303.3 shall be an iterative process. It shall be used to determine the acceptable impact of certain events based on their magnitude, and then used iteratively to evaluate various designed mitigation features. Assignment of performance groups is accomplished through consideration of building or facility uses, building or facility risk factors, and the importance of a building or facility to a community.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[BG] 303.4 Performance groups. There are four performance groups (PG), identified as I, II, III and IV.</p>												
<p>[BG] 303.4.1 Performance Group I. The minimum design performance level with which all buildings or facilities posing a low risk to human life, should the buildings or facilities fail, shall comply.</p>												
<p>[BG] 303.4.2 Performance Group II. The minimum design performance level with which all buildings or facilities subject to this code, except those classified as PG I, PG III or PG IV, shall comply.</p>												
<p>[BG] 303.4.3 Performance Group III. The minimum design performance level with which buildings or facilities of an increased level of societal benefit or importance shall comply.</p>												
<p align="center">[BG]TABLE 303.1</p>												
<p>PERFORMANCE GROUP CLASSIFICATIONS FOR BUILDINGS AND FACILITIES</p>												
<table border="1"> <thead> <tr> <th>PERFORMANCE GROUP</th> <th>USE AND OCCUPANCY CLASSIFICATIONS FOR SPECIFIC BUILDINGS OR FACILITIES</th> </tr> </thead> <tbody> <tr> <td align="center">I</td> <td>Buildings and facilities that represent a low hazard to human life in the event of failure, including, but not limited to: 1. Agricultural facilities. 2. Certain temporary facilities. 3. Minor storage facilities.</td> </tr> <tr> <td align="center">II</td> <td>All buildings and facilities except those listed in Performance Groups I, III and IV.</td> </tr> <tr> <td align="center">III</td> <td>Buildings and facilities that represent a substantial hazard to human life in the event of failure, including, but not limited to: 1. Buildings and facilities where more than 300 people congregate in one area. 2. Buildings and facilities with elementary school, secondary school or day care facilities with a capacity greater than 250. 3. Buildings and facilities with a capacity greater than 500 for colleges or adult education facilities. 4. Health-care facilities with a capacity of 50 or more residents but not having surgery or emergency treatment facilities. 5. Jails and detention facilities. 6. Any other occupancy with an occupant load greater than 5,000. 7. Power-generating facilities, water treatment for potable water, wastewater treatment facilities and other public utilities facilities not included in Performance Group IV. 8. Buildings and facilities not included in Performance Group IV containing sufficient quantities of highly toxic gas or explosive materials capable of causing acutely hazardous conditions that do not extend beyond property boundaries.</td> </tr> <tr> <td align="center">IV</td> <td>Buildings and facilities designated as essential facilities, including, but not limited to: 1. Hospitals and other health-care facilities having surgery or emergency treatment facilities. 2. Fire, rescue and police stations and emergency vehicle garages. 3. Designated earthquake, hurricane or other emergency shelters. 4. Designated emergency preparedness, communication, and operation centers and other facilities required for emergency response. 5. Power-generating stations and other utilities required as emergency backup facilities for Performance Group IV buildings or facilities. 6. Buildings and facilities containing highly toxic gas or explosive materials capable of causing acutely hazardous conditions beyond the property boundaries. 7. Aviation control towers, air traffic control centers and emergency aircraft hangars. 8. Buildings and facilities having critical national defense functions. 9. Water treatment facilities required to maintain water pressure for fire suppression. 10. Ancillary structures (including, but not limited to, communication towers, fuel storage tanks or other structures housing or supporting water or other fire suppression material or equipment) required for operation of Performance Group IV structures during an emergency.</td> </tr> </tbody> </table>	PERFORMANCE GROUP	USE AND OCCUPANCY CLASSIFICATIONS FOR SPECIFIC BUILDINGS OR FACILITIES	I	Buildings and facilities that represent a low hazard to human life in the event of failure, including, but not limited to: 1. Agricultural facilities. 2. Certain temporary facilities. 3. Minor storage facilities.	II	All buildings and facilities except those listed in Performance Groups I, III and IV.	III	Buildings and facilities that represent a substantial hazard to human life in the event of failure, including, but not limited to: 1. Buildings and facilities where more than 300 people congregate in one area. 2. Buildings and facilities with elementary school, secondary school or day care facilities with a capacity greater than 250. 3. Buildings and facilities with a capacity greater than 500 for colleges or adult education facilities. 4. Health-care facilities with a capacity of 50 or more residents but not having surgery or emergency treatment facilities. 5. Jails and detention facilities. 6. Any other occupancy with an occupant load greater than 5,000. 7. Power-generating facilities, water treatment for potable water, wastewater treatment facilities and other public utilities facilities not included in Performance Group IV. 8. Buildings and facilities not included in Performance Group IV containing sufficient quantities of highly toxic gas or explosive materials capable of causing acutely hazardous conditions that do not extend beyond property boundaries.	IV	Buildings and facilities designated as essential facilities, including, but not limited to: 1. Hospitals and other health-care facilities having surgery or emergency treatment facilities. 2. Fire, rescue and police stations and emergency vehicle garages. 3. Designated earthquake, hurricane or other emergency shelters. 4. Designated emergency preparedness, communication, and operation centers and other facilities required for emergency response. 5. Power-generating stations and other utilities required as emergency backup facilities for Performance Group IV buildings or facilities. 6. Buildings and facilities containing highly toxic gas or explosive materials capable of causing acutely hazardous conditions beyond the property boundaries. 7. Aviation control towers, air traffic control centers and emergency aircraft hangars. 8. Buildings and facilities having critical national defense functions. 9. Water treatment facilities required to maintain water pressure for fire suppression. 10. Ancillary structures (including, but not limited to, communication towers, fuel storage tanks or other structures housing or supporting water or other fire suppression material or equipment) required for operation of Performance Group IV structures during an emergency.		
PERFORMANCE GROUP	USE AND OCCUPANCY CLASSIFICATIONS FOR SPECIFIC BUILDINGS OR FACILITIES											
I	Buildings and facilities that represent a low hazard to human life in the event of failure, including, but not limited to: 1. Agricultural facilities. 2. Certain temporary facilities. 3. Minor storage facilities.											
II	All buildings and facilities except those listed in Performance Groups I, III and IV.											
III	Buildings and facilities that represent a substantial hazard to human life in the event of failure, including, but not limited to: 1. Buildings and facilities where more than 300 people congregate in one area. 2. Buildings and facilities with elementary school, secondary school or day care facilities with a capacity greater than 250. 3. Buildings and facilities with a capacity greater than 500 for colleges or adult education facilities. 4. Health-care facilities with a capacity of 50 or more residents but not having surgery or emergency treatment facilities. 5. Jails and detention facilities. 6. Any other occupancy with an occupant load greater than 5,000. 7. Power-generating facilities, water treatment for potable water, wastewater treatment facilities and other public utilities facilities not included in Performance Group IV. 8. Buildings and facilities not included in Performance Group IV containing sufficient quantities of highly toxic gas or explosive materials capable of causing acutely hazardous conditions that do not extend beyond property boundaries.											
IV	Buildings and facilities designated as essential facilities, including, but not limited to: 1. Hospitals and other health-care facilities having surgery or emergency treatment facilities. 2. Fire, rescue and police stations and emergency vehicle garages. 3. Designated earthquake, hurricane or other emergency shelters. 4. Designated emergency preparedness, communication, and operation centers and other facilities required for emergency response. 5. Power-generating stations and other utilities required as emergency backup facilities for Performance Group IV buildings or facilities. 6. Buildings and facilities containing highly toxic gas or explosive materials capable of causing acutely hazardous conditions beyond the property boundaries. 7. Aviation control towers, air traffic control centers and emergency aircraft hangars. 8. Buildings and facilities having critical national defense functions. 9. Water treatment facilities required to maintain water pressure for fire suppression. 10. Ancillary structures (including, but not limited to, communication towers, fuel storage tanks or other structures housing or supporting water or other fire suppression material or equipment) required for operation of Performance Group IV structures during an emergency.											

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>304.2.1.1 Structural damage. The building or facility does not have structural damage and is safe to occupy.</p>		
<p>304.2.1.2 Nonstructural systems. Nonstructural systems needed for normal building or facility use and emergency operations are fully operational.</p>		
<p>[BG] 304.2.1.3 Occupant hazards. Injuries to building or facility occupants from hazard-related applied loads are minimal in numbers and minor in nature. There is a very low likelihood of single or multiple life loss. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		
<p>[BG] 304.2.1.4 Overall extent of damage. Damage to building or facility contents from hazard-related applied loads is minimal in extent and minor in cost.</p>		
<p>[BG] 304.2.1.5 Hazardous materials. Minimal hazardous materials are released to the environment.</p>		
<p>[BG] 304.2.2 Moderate impact. The tolerable impacts of the design loads are assumed as follows:</p>		
<p>[BG] 304.2.2.1 Structural damage. There is moderate structural damage, which is repairable; some delay in reoccupancy can be expected.</p>		
<p>[BG] 304.2.2.2 Nonstructural systems. Nonstructural systems needed for normal building or facility use are fully operational, although some cleanup and repair may be needed. Emergency systems remain fully operational.</p>		
<p>[BG] 304.2.2.3 Occupant hazards. Injuries to building or facility occupants from hazard-related applied loads may be locally significant, but generally moderate in numbers and in nature. There is a low likelihood of single life loss with a very low likelihood of multiple life loss. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[BG] 304.2.2.4 Overall extent of damage. Damage to building or facility contents from hazard-related applied loads may be locally significant, but is generally moderate in extent and cost. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		
<p>[BG] 304.2.2.5 Hazardous materials. Some hazardous materials are released to the environment, but the risk to the community is minimal. Emergency relocation is not necessary.</p>		
<p>[BG] 304.2.3 High impact. The tolerable impacts of the design loads are assumed as follows:</p>		
<p>[BG] 304.2.3.1 Structural damage. There is significant damage to structural elements but there is not large falling debris; repair is possible. Significant delays in reoccupancy can be expected.</p>		
<p>[BG] 304.2.3.2 Nonstructural systems. Nonstructural systems needed for normal building or facility use are significantly damaged and inoperable; egress routes may be impaired by light debris; emergency systems may be significantly damaged, but remain operational.</p>		
<p>[BG] 304.2.3.3 Occupant hazards. Injuries to building or facility occupants from hazard-related applied loads may be locally significant with a high risk to life, but are generally moderate in numbers and in nature. There is a moderate likelihood of single life loss, with a low probability of multiple life loss. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		
<p>[BG] 304.2.3.4 Overall extent of damage. Damage to building or facility contents from hazard-related applied loads may be locally total and generally significant. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		
<p>[BG] 304.2.3.5 Hazardous materials. Hazardous materials are released to the environment with localized relocation needed for buildings and facilities in the immediate vicinity.</p>		
<p>[BG] 304.2.4 Severe impact. The tolerable impacts of the design loads are assumed as follows:</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[BG] 304.2.4.1 Structural damage. There is substantial structural damage, but all significant components continue to carry gravity load demands. Repair may not be technically possible. The building or facility is not safe for reoccupancy, as reoccupancy could cause collapse.</p>		
<p>[BG] 304.2.4.2 Nonstructural systems. Nonstructural systems for normal building or facility use may be completely nonfunctional. Egress routes may be impaired; emergency systems may be substantially damaged and nonfunctional.</p>		
<p>[BG] 304.2.4.3 Occupant hazards. Injuries to building or facility occupants from hazard-related applied loads may be high in numbers and significant in nature. Significant risk to life may exist. There is a high likelihood of single life loss and a moderate likelihood of multiple life loss. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		
<p>[BG] 304.2.4.4 Overall extent of damage. Damage to building or facility contents from hazard-related applied loads may be total. The nature of the applied load, such as fire hazards, may result in higher levels of expected injuries and damage in localized areas, whereas the balance of the areas may sustain fewer injuries and less damage.</p>		
<p>[BG] 304.2.4.5 Hazardous materials. Significant hazardous materials are released to the environment, with relocation needed beyond the immediate vicinity.</p>		
<p style="text-align: center;">SECTION 305 MAGNITUDES OF EVENT</p> <p>[BG] 305.1 General. Magnitude of event encompasses all loads that can be reasonably expected to impact on a building or facility, its users and its contents, during construction and throughout its intended life. This includes building and facility-related and occupancy-related loads, as well as loads resulting from natural and technological hazards. Determination of magnitude of event shall take into account the design performance levels established by this code, the risk factors identified in Section 302.4 and specific performance criteria established by relevant authoritative documents.</p>		
<p>[BG] 305.1.1 Natural hazards. The types of loads affecting main-force-resisting systems, components and contents that may be reasonably expected to impact on the building or facility, its users and its contents during its intended life are provided in Chapter 5 of this code.</p>		
<p>[BG] 305.1.2 Technological hazards. The types of loads due to technological hazards that may be reasonably expected to impact on the building or facility, its users and its contents during construction and throughout its intended life include, but are not limited to:</p>		
<p>[BG] 305.1.2.1 Fires (Chapters 6, 16 and 17).</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 305.1.2.2 Explosions (Chapters 5, 22 and Section 801).</p>		
<p>[BG] 305.1.2.3 Toxic materials (Chapter 22 and Section 801).</p>		
<p>[BG] 305.1.2.4 Corrosive materials (Chapter 22 and Section 801).</p>		
<p>[BG] 305.1.2.5 Infectious materials or agents (Chapter 22 and Section 801).</p>		
<p>[BG] 305.2 Definition of magnitude of event. Magnitude of event can be defined, quantified and expressed either deterministically or probabilistically in accordance with the best current practice of the relevant profession as published in recognized authoritative documents. In some authoritative documents, magnitude of event may be expressed only for a single performance group; for example, nominal live and dead loads are defined only for Performance Group II. In other cases, magnitude of event may be provided for all performance levels such as seismic provisions. In all cases, it is the responsibility of the design engineer to demonstrate that the design performance levels are met for the loads anticipated.</p>		
<p>[BG] 305.2.1 Classification of event magnitude. For the purpose of this code, the magnitude of event shall be classified as: small, medium, large and very large. Where authoritative documents do not present magnitude of event in this format, it will be the responsibility of the designer to relate the loads to this format and to demonstrate that the minimum design performance levels will be met by the proposed design.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

**Chapter 4
RELIABILITY AND DURABILITY**

2021 Proposed

Code Analysis

**SECTION 401
RELIABILITY**

[BG] 401.1 Objective. To ensure reliability of the system necessary to meeting the performance objectives of building, facility or processes in accordance with the design

[BG] 401.2 Functional statements.

[BG] 401.2.1 Design, installation and maintenance. Design, install and maintain systems, system components and equipment that provide a safety function in strict accordance with the manufacturers' instructions and with any applicable codes and standards.

[BG] 401.2.2 Testing and inspection. Test and inspect systems, system components and equipment that provide a safety function in strict accordance with the manufacturers' instructions and with any applicable codes and standards for both the methods employed and the frequency.

[BG] 401.2.3 Active fire protection systems. Active fire protection systems such as fire alarm, suppression and smoke management systems shall undergo commissioning testing when first placed into service or following any substantial alteration.

[BG] 401.2.4 Training. Provide appropriate training to any people who operate, test, maintain or interpret information from any safety systems. Where such work is done by contractors, ensure that they have the necessary training and skills.

[BG] 401.3 Performance requirements.

[BG] 401.3.1 Qualifications. Design, installation and maintenance shall be performed only by qualified people as approved. Certification or records of training shall be provided.

[BG] 401.3.2 Documentation. Documentation shall be maintained at the building that details the systems installed and their required maintenance and testing methods and frequency. Records of such maintenance and testing shall be maintained that demonstrate compliance, the persons conducting the work and their qualifications.

**SECTION 402
DURABILITY**

[BG] 402.1 Objective. To assist in the selection of appropriate materials and construction systems.

[BG] 402.2 Functional statement. To ensure that a building will continue to satisfy the objectives of this code throughout its life.

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 402.2 Functional statement. To ensure that a building will continue to satisfy the objectives of this code throughout its life.</p>		
<p>[BG] 402.3 Performance requirements. [BG] 402.3.1 Normal maintenance. From the time a certificate of occupancy is issued, primary building elements shall, with only normal maintenance, continue to satisfy the performance requirements of this code for the intended life of the building.</p>		
<p>[BG] 402.3.2 Intended life of a building. Where the useful life of building or facility elements or systems is less than the intended life of the building, provisions shall be made for timely replacement of those elements, so that the objective of this code and the design are maintained.</p>		
<p>[BG] 402.3.3 Damage and deterioration. Where damage or deterioration to building or facility elements or systems will impact the objectives of this code or the design, those elements or systems shall be repaired or replaced in order to maintain the level of performance intended by this code.</p>		
<p>[BG] 402.3.4 Determination of durability and service life. In determining the useful service life of building elements, products or systems, an acceptable method for determining durability and service life shall be used.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 5 STABILITY	2021 Proposed	Code Analysis
<p align="center">SECTION 501 STRUCTURAL FORCES</p> <p>[BS] 501.1 Objective. To provide a desired level of structural performance when structures are subjected to the loads that are expected during construction or alteration and throughout their intended lives.</p>		
<p>[BS] 501.2 Functional statements. [BS] 501.2.1 Life safety and injury prevention. Structures shall be designed and constructed to prevent injury to occupants due to loading of a structural element or system consistent with the design performance level determined in Chapter 3.</p>		
<p>[BS] 501.2.2 Property and amenity protection. Structures shall be designed and constructed to prevent loss of property and amenity consistent with the design performance level determined in Chapter 3.</p>		
<p>[BS] 501.3 Performance requirements. [BS] 501.3.1 Stability. Structures, or portions thereof, shall remain stable and not collapse during construction or alteration and throughout their lives.</p>		
<p>[BS] 501.3.2 Disproportionate failure. Structures shall be designed to sustain local damage, and the structural system as a whole shall remain stable and not be damaged to an extent disproportionate to the original local damage.</p>		
<p>[BS] 501.3.3 Loss of amenity. Structures, or portions thereof, shall have a low probability of causing damage or loss of amenity through excessive deformation, vibration or degradation during construction or alteration and throughout their lives.</p>		
<p>[BS] 501.3.4 Expected loads. Structures, or portions thereof, shall be designed and constructed taking into account expected loads, and combination of loads, associated with the event(s) magnitude(s) that would affect their performance, including, but not limited to:</p> <ol style="list-style-type: none"> 1. Dead loads. 2. Live loads. 3. Impact loads. 4. Explosion loads. 5. Soil and hydrostatic pressure loads. 6. Flood loads (mean return period). <ol style="list-style-type: none"> 6.1 Small: 100 years 6.2 Medium: 500 years 6.3 Large: Determined on a site-specific basis 6.4 Very Large: Determined on a site-specific basis 7. Wind loads (mean return period). <ol style="list-style-type: none"> 7.1 Small: 300 years 7.2 Medium: 700 years 7.3 Large: 1700 years 7.4 Very Large: 3000 years 		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

- 8. Windborne debris loads.
- 9. Snow loads (mean return period).
 - 9.1 Small: 25 years
 - 9.2 Medium: 50 years
 - 9.3 Large: 100 years
 - 9.4 Very Large: 500 years
- 10. Rain loads. See Table 501.3.4.
- 11. Earthquake loads.
 - 11.1 Small: 43 years (mean return period)
 - 11.2 Medium: 72 years (mean return period)
 - 11.3 Large: Two-thirds of the intensity of very large loads
 - 11.4 Very large: The Risk-Targeted Maximum Considered Earthquake defined in Chapter 21 of ASCE 7.
- 12. Ice loads, atmospheric icing (mean return period).
 - 12.1 Small: 25 years
 - 12.2 Medium: 50 years
 - 12.3 Large: 100 years
 - 12.4 Very Large: 200 years
- 13. Hail loads.
- 14. Thermal loads.

**[BS] TABLE 501.3.4
RAIN LOADS**

MAGNITUDE OF EVENT	DRAINAGE SYSTEM	MRI (YEARS)	STORM DURATION (MIN.)
Small	Primary	25	60
Small	Secondary	25	15
Medium	Primary	50	60
Medium	Secondary	50	15
Large	Primary	100	60
Large	Secondary	100	15
Very Large	Primary	100	30
Very Large	Secondary	100	10

[BS] 501.3.5 Safety factors. The design of buildings and structures shall consider appropriate factors of safety to provide adequate performance from:

- 1. Effects of uncertainties resulting from construction activities.
- 2. Variation in the properties of materials and the characteristics of the site.
- 3. Accuracy limitations inherent in the methods used to predict the stability of the building.
- 4. Self-straining forces arising from differential settlements of foundations and from restrained dimensional changes due to temperature, moisture, shrinkage, creep and similar effects.
- 5. Uncertainties in the determination of the expected loads.

[BS] 501.3.6 Demolition and alteration. The demolition or alteration of buildings and structures shall be carried out in a way that avoids the likelihood of premature collapse.

[BS] 501.3.7 Site work. Site work, where necessary, shall be carried out to provide stability for construction on the site and avoid the likelihood of damage to adjacent property.

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 6 FIRE SAFETY	2021 Proposed	Code Analysis
<p align="center">SECTION 601 SOURCES OF FIRE IGNITION</p> <p>[F] 601.1 Objective. To prevent unwanted ignition caused by building equipment and systems.</p>		
<p>[F] 601.2 Functional statements. [F] 601.2.1 Fuel-burning appliances and services. Fuel-burning appliances and services shall be installed in a manner that reduces their potential as sources of fire ignition.</p>		
<p>[F] 601.2.2 Electrical equipment, appliances and services. Electrical equipment, appliances and services shall be installed in a manner that reduces their potential as sources of fire ignition.</p>		
<p>[F] 601.3 Performance requirements. [F] 601.3.1 Uncontrolled combustion and explosion. Fuel-burning appliances and services shall be installed so that the appliance or service will not cause uncontrolled combustion or explosion.</p>		
<p>[F] 601.3.2 Fuel-burning appliances and services as sources of ignition. Fuel-burning appliances and services shall be installed so that they will not become sources of ignition.</p>		
<p>[F] 601.3.3 Sparks and arcing. Electrical equipment, appliances and services shall be installed so that they will not allow sparks or arcing to escape their enclosures.</p>		
<p>[F] 601.3.4 Electrical equipment, appliances and services. Electrical equipment, appliances and services shall be installed so that they will not become sources of ignition.</p>		
<p>[F] 601.3.5 Flammable, combustible and explosive atmospheres. Separate ignition sources from areas where a flammable, combustible or explosive atmosphere may exist.</p>		
<p align="center">SECTION 602 LIMITING FIRE IMPACT</p> <p>[F] 602.1 Objective. To provide an acceptable level of fire safety performance when facilities are subjected to fires occurring in the fire loads that may be present in the facility during construction or alteration and throughout the intended life.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 602.2 Functional statement. Buildings shall be designed with safeguards against the spread of fire so that persons not directly adjacent to or involved in the ignition of a fire shall not suffer serious injury or death from a fire and so that the magnitude of the property losses are limited as follows: Performance Group I—High Performance Group II—Moderate Performance Group III—Mild Performance Group IV—Mild</p>		
<p>[F] 602.2.1 Building and adjacent buildings. Buildings and facilities shall be designed and constructed so that the building and adjacent buildings or facilities and their occupants, contents and amenities are appropriately protected from the impact of fire and smoke.</p>		
<p>[F] 602.2.2 Needs of fire fighters. Buildings and facilities shall be designed and constructed so that fire fighters can appropriately perform rescue operations, protect property and utilize fire-fighting equipment and controls.</p>		
<p>[F] 602.3 Performance requirements. See Section 1701.3.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 7 PEDESTRIAN CIRCULATION	2021 Proposed	Code Analysis
<p align="center">SECTION 701 MEANS OF EGRESS</p> <p>[BE] 701.1 Objective. To protect people during egress and rescue operations.</p>		
<p>[BE] 701.2 Functional statement. Enable occupants to exit the building, facility and premises or reach a safe place as appropriate to the design performance level determined in Chapter 3.</p>		
<p>[BE] 701.3 Performance requirements. See Section 1901.3.</p>		
<p align="center">SECTION 702 ACCESSIBILITY</p> <p>[BE] 702.1 Objective. To provide people with disabilities reasonable use of the built environment in a manner consistent with that provided to people without disabilities in nonemergency conditions.</p>		
<p>[BE] 702.2 Functional statement. Buildings and their site-adjacent facilities shall allow all people, including but not limited to people with disabilities, functional use of spaces based on a space's intended purpose.</p>		
<p>[BE] 702.3 Performance requirements. Safe and usable routes shall be provided that allow people to:</p> <ol style="list-style-type: none"> 1. Approach, enter and leave buildings and sites to and from adjacent transportation stops, walkways and parking areas. 2. Move within and use building and site spaces based on a facility's intended purpose. 		
<p align="center">SECTION 703 TRANSPORTATION EQUIPMENT</p> <p>[BG] 703.1 Objective. To ensure the safety of all people using, maintaining and inspecting elevators, escalators and similar building transportation equipment inside or outside of buildings.</p>		
<p>[BG] 703.2 Functional statement. Building transportation equipment installations for access into, within and outside of buildings shall provide for the safe movement of all people and the safety of maintenance and inspection personnel.</p>		
<p>[BG] 703.3 Performance requirements.</p> <p>703.3.1 General. Building transportation equipment shall:</p> <ol style="list-style-type: none"> 1. Move people safely when starting, stopping, accelerating, decelerating or changing direction of travel, and hold the rated loads. 2. Be constructed to avoid the likelihood of people falling, tripping, becoming caught and coming in contact with sharp edges or projections under normal and reasonably foreseeable conditions of use. 3. Be guided and have sufficient running clearances. 		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>4. Have controls to stop and prevent restarting in the event of activation of a safety device. 5. Be capable of being isolated for inspection, testing and maintenance. 6. Have adequate lighting and ventilation during normal conditions or upon loss of normal power.</p>		
<p>[BG] 703.3.2 Elevators. Elevators shall be designed and constructed to provide: 1. A means of communication for trapped passengers in stalled elevators. 2. Emergency recall operation that discharges passengers at the required designated or alternate landing in the event of a fire emergency. 3. Emergency in-car operation for fire-fighting and rescue operations. 4. An environment that ensures the safe operation of the equipment for the anticipated use or application.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 8 SAFETY OF USERS	2021 Proposed	Code Analysis
<p align="center">SECTION 801 HAZARDOUS MATERIALS</p> <p>[F] 801.1 Objective. To protect people and property from the consequences of unauthorized discharge, fires or explosions involving hazardous materials.</p>		
<p>[F] 801.2 Functional statements. [F] 801.2.1 Prevention. Provide adequate safeguards to minimize the risk of unwanted releases, fires or explosions involving hazardous materials as appropriate to the design performance level determined in Chapter 3.</p>		
<p>[F] 801.2.2 Mitigation. Provide adequate safeguards to minimize the consequences of an unsafe condition involving hazardous materials during normal operations and in the event of an abnormal condition in accordance with the design performance level determined in Chapter 3.</p>		
<p>[F] 801.3 Performance requirements. See Section 2201.3</p>		
<p align="center">SECTION 802 HAZARDS FROM BUILDING MATERIALS</p> <p>[BG] 802.1 Objective. To safeguard people from injury caused by exposure to hazards from building materials.</p>		
<p>[BG] 802.2 Functional statement. Building materials that are potentially hazardous shall be used in ways to avoid undue risk to people</p>		
<p>[BG] 802.3 Performance requirements. [BG] 802.3.1 Construction materials. The quantities of gas, liquid, radiation or solid particles emitted by materials used in the construction of buildings shall not give rise to harmful concentrations at the surface of the material where the material is exposed or in the atmosphere of any space.</p>		
<p>[BG] 802.3.2 Glazing. Glass or other brittle materials with which people are likely to come into contact shall comply with one or more of the following: 1. If broken upon impact, break in a way that is unlikely to cause injury. 2. Resist a reasonably foreseeable impact without breaking. 3. Be reasonably protected from impact.</p>		
<p align="center">SECTION 803 PREVENTION OF FALLS</p> <p>[BG] 803.1 Objective. To prevent people from unintentionally falling from one level to another.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 803.2 Functional statement. Buildings and their facilities shall be constructed to reduce the likelihood of unintentional falls.</p>		
<p>[BG] 803.3 Performance requirements. [BG] 803.3.1 Required barriers. A barrier shall be provided where people could fall 30 inches (762 mm) or more from an opening in the external envelope or floor of a building or its facilities.</p>		
<p>[BG] 803.3.2 Roofs. Roofs with permanent access shall have barriers provided.</p>		
<p>[BG] 803.3.3 Barrier construction. Barriers shall be constructed and installed appropriate to the hazard.</p>		
<p>[BG] 803.3.4 Openings in barriers. Where barriers have openings, the openings shall be of an appropriate size and configuration to keep people from falling through based on the anticipated age of the occupants.</p>		
<p style="text-align: center;">SECTION 804 CONSTRUCTION AND DEMOLITION HAZARDS</p> <p>[BG] 804.1 Objective. To safeguard people from injury or illness and to protect property from damage during the construction or demolition processes.</p>		
<p>[BG] 804.2 Functional statement. Provisions are required during construction and demolition work to:</p> <ol style="list-style-type: none"> 1. Protect authorized personnel from injury resulting from falling objects, fire, blasts, tripping or falling, or any other risk posed by the construction or demolition operation. 2. Prevent the entry of unauthorized personnel on the construction or demolition site. 3. Protect property off site from damage resulting from falling objects, fire, blasts or any other risk posed by the construction or demolition operations. 		
<p>[BG] 804.3 Performance requirements. [BG] 804.3.1 Operations and procedures. Sequencing of tasks, procedural methods and equipment shall be such that:</p> <ol style="list-style-type: none"> 1. Personnel are protected from injury and illness attributable to hazards present because of the given operation. 2. Adjacent property, property on site and equipment are protected from damage from execution of the given tasks. 3. Safety procedures limit the accumulation of combustible materials on site and provide safe-guards for equipment and operations that represent ignition sources. 		
<p>[BG] 804.3.2 Protection from natural hazards. The structure under construction shall be protected from damage due to wind, rain or other natural hazards likely to occur during construction.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 804.3.3 Protection of personnel. Provisions for personnel movement, transport and support shall be such that:</p> <ol style="list-style-type: none"> 1. Personnel are protected from injury due to falling. 2. Personnel are protected from injury due to falling objects. 3. Personnel are protected from injury that could be caused by the particular operations being conducted. 4. Exposure to materials that are known to be health hazards is eliminated. 		
<p>[BG] 804.3.4 Unauthorized entry. The job site shall be protected from the intrusion of unauthorized personnel.</p>		
<p style="text-align: center;">SECTION 805 SIGNS</p> <p>[F] 805.1 Objective. To identify essential features of the building to its users.</p>		
<p>[F] 805.2 Functional statement. Signs shall identify escape and rescue routes, hazards, accessible elements where not all elements are accessible and other essential features of a building.</p>		
<p>[F] 805.3 Performance requirements. [F] 805.3.1 Visibility. Signs shall be clearly visible and readily recognizable under the conditions expected for their purpose.</p>		
<p>[F] 805.3.2 Identification of exits and safe places. Signs shall identify exits and safe places, and be located sufficiently to mark escape/rescue routes and guide people to exits and safe places.</p>		
<p>[F] 805.3.3 Power failure. Signs that identify exits, safe places and escape/rescue routes shall remain visible in the event of a power failure.</p>		
<p>[F] 805.3.4 Hazard identification. Signs indicating hazards shall be provided in sufficient locations to notify people before they encounter the hazard.</p>		
<p>[F] 805.3.5 Accessible building feature signage. Signs shall identify accessible facilities and be located sufficiently to mark accessible routes.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

SECTION 806 EMERGENCY NOTIFICATION		
<p>[F] 806.1 Objective. To provide notification of the need to take some manual action to preserve the safety of occupants or to limit property damage.</p>		
<p>[F] 806.2 Functional statements. [F] 806.2.1 Occupant notification. Where required, adequate means of occupant notification shall be provided to warn of the presence of a fire or other emergency in sufficient time to enable occupants to take the contemplated action without being exposed to unreasonable risk of injury or death.</p>		
<p>[F] 806.2.2 Emergency responder notification. Where systems are designed to notify emergency responders, such systems shall indicate the type of emergency and the location of the building. Where buildings are large enough to expect difficulty in prompt location of the fire or other public emergency, identification of the fire zone of origin shall be provided at the building.</p>		
<p>[F] 806.3 Performance requirements. [F] 806.3.1 Type of notification. Notification of occupants shall be by means appropriate to the needs of the occupants, the use of the building and the emergency egress strategy employed.</p>		
<p>[F] 806.3.2 Sleeping occupants. Where required by the anticipated use of the building, notification systems shall be capable of alerting sleeping occupants in reasonable time to enable them to reach a safe place before the occurrence of untenable conditions at any point along the primary egress path.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 9 MOISTURE	2021 Proposed	Code Analysis
<p align="center">SECTION 901 SURFACE WATER</p> <p>[BS] 901.1 Objective. To safeguard people from injury and protect the building or other property from damage caused by surface water and to protect outfalls of drainage systems that may become contaminated from on-site hazardous material storage.</p>		
<p>[BS] 901.2 Functional statements. [BS] 901.2.1 Surface water hazards. Buildings and sites shall be constructed in a way that protects people and other property from the adverse effects of surface water.</p>		
<p>[BS] 901.2.2 Hazardous materials contamination. Building or building sites used for the storage or use of hazardous materials shall include provisions to ensure that hazardous materials are not accidentally transported across property lines into drainage outfalls.</p>		
<p>[BS] 901.3 Performance requirements. [BS] 901.3.1 Removal of surface water. Surface water shall be removed in a manner that avoids damage or nuisance to the building or other property.</p>		
<p>[BS] 901.3.2 Contaminated water. Surface water or water used for fire fighting and other uses shall be routed so as not to transport hazardous material across property lines or into drainage outfalls.</p>		
<p>[BS] 901.3.3 Surface water runoff. Surface water drainage systems shall convey surface water runoff to an appropriate outfall.</p>		
<p>[BS] 901.3.4 Blockage. Drainage systems shall be constructed so as to avoid the likelihood of blockage.</p>		
<p>[BS] 901.3.5 Access for cleaning. Drainage systems shall be constructed so as to have reasonable access for cleaning.</p>		
<p align="center">SECTION 902 EXTERNAL MOISTURE</p> <p>[BS] 902.1 Objective. To safeguard people from injury and property from damage that could result from external moisture entering the building.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BS] 902.2 Functional statement. Buildings shall be constructed to provide adequate resistance to penetration by, and the accumulation of, moisture from the outside.</p>		
<p>[BS] 902.3 Performance requirements. [BS] 902.3.1 Water penetration. Roofs and exterior walls shall prevent the penetration of water that could cause damage to building elements</p>		
<p>[BS] 902.3.2 Building elements in contact with the ground. Walls, floors and structural elements in contact with the ground shall not absorb or transmit moisture in quantities that could cause damage to building elements.</p>		
<p>[BS] 902.3.3 Concealed spaces and cavities. Concealed spaces and cavities in buildings shall be constructed in a way that prevents external moisture from causing degradation of building elements.</p>		
<p>[BS] 902.3.4 Moisture during construction. Excess moisture present at the completion of construction shall be capable of being dissipated without permanent damage to building elements.</p>		
<p style="text-align: center;">SECTION 903 INTERNAL MOISTURE</p> <p>[BS] 903.1 Objective. To safeguard people against illness or injury that could result from accumulation of internal moisture, and to protect an occupancy from damage caused by free water from another occupancy in the same building.</p>		
<p>[BS] 903.2 Functional statement. Buildings shall be constructed to avoid the likelihood of:</p> <ol style="list-style-type: none"> 1. Fungal growths or the accumulation of contaminants on linings and other building elements. 2. Free water overflow penetrating to an adjoining occupancy. 3. Damage to building elements being caused by the use of water. 		
<p>[BS] 903.3 Performance requirements. [BS] 903.3.1 Excess moisture removal and protection. An adequate means shall be provided to remove excess moisture from the structure or protect it from the effects of excess moisture and condensation in all habitable spaces, bathrooms, laundries and other locations where moisture is potentially generated.</p>		
<p>[BS] 903.3.2 Overflow. Accidental overflow from sanitary fixtures or laundering facilities shall be constrained from penetrating another occupancy in the same building.</p>		
<p>[BS] 903.3.3 Floor surfaces. Floor surfaces of any space containing sanitary fixtures or laundering facilities shall be impervious to water and easily cleaned.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BS] 903.3.4 Wall surfaces. Wall surfaces adjacent to sanitary fixtures or laundering facilities shall be impervious to water and easily cleaned.</p>		
<p>[BS] 903.3.5 Surfaces and building elements. Surfaces of building elements likely to be splashed or to become contaminated in the course of the intended use of the building shall be impervious to water and easily cleaned.</p>		
<p>[BS] 903.3.6 Water splash. Water splash shall be prevented from penetrating behind linings or into concealed spaces.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 10 INTERIOR ENVIRONMENT	2021 Proposed	Code Analysis
<p align="center">SECTION 1001 CLIMATE AND BUILDING FUNCTIONALITY</p> <p>[BG] 1001.1 Objective. To safeguard people from illness caused by air temperature and to safeguard people from injury or loss of amenity caused by inadequate activity space.</p>		
<p>[BG] 1001.2 Functional statements. Buildings shall be constructed to provide:</p> <ol style="list-style-type: none"> 1. Adequately controlled interior temperatures. 2. Adequate activity space for the intended use. 		
<p>[BG] 1001.3 Performance requirements. [BG] 1001.3.1 Temperature. Habitable spaces, bathrooms and recreation rooms shall be designed to maintain the internal temperature at a level sufficient for the occupants while the space is adequately ventilated.</p>		
<p>[BG] 1001.3.2 Space. Habitable spaces shall have sufficient space for activity, furniture and sanitary needs of the occupants.</p>		
<p align="center">SECTION 1002 INDOOR AIR QUALITY</p> <p>[BG] 1002.1 Objective. To maintain the habitable spaces of buildings and facilities with an environment that is conducive to the comfort, health and safety of the occupants.</p>		
<p>[BG] 1002.2 Functional statement. Habitable spaces within buildings shall be provided with air that contains sufficient oxygen and limits the levels of moisture and contaminants to levels that are consistent with good health, safety and comfort.</p>		
<p>[BG] 1002.3 Performance requirements. [BG] 1002.3.1 Ventilation. Habitable spaces within buildings shall have a means of ventilation that maintains air quality at all times that the spaces are occupied and with the maximum number of occupants anticipated.</p>		
<p>[BG] 1002.3.2 Collection and removal. Buildings shall have a means of collecting or otherwise removing the following products from the spaces in which they are generated:</p> <ol style="list-style-type: none"> 1. Cooking fumes and odors 2. Excessive water vapor from laundering, utensil washing, bathing and showering. 3. Odors from sanitary and waste storage spaces. 4. Gaseous byproducts and excessive moisture from commercial or industrial processes. 5. Poisonous fumes and gases. 6. Airborne particles. 7. Products of combustion. 8. Off-gases from building materials, fixtures and contents. 		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 1002.3.3 Building materials. Building materials that release quantities of contaminants that cannot be maintained at safe levels shall not be used.</p>		
<p>[BG] 1002.3.4 Contaminated air. Contaminated air shall be disposed of in a way that avoids creating a nuisance or hazard to people and other property.</p>		
<p>[BG] 1002.3.5 Sufficient supply air. The quantity of air supplied for ventilation shall account for the demands of any fixed combustion appliances.</p>		
<p style="text-align: center;">SECTION 1003 AIRBORNE AND IMPACT SOUND</p> <p>[BG] 1003.1 Objective. To safeguard people from loss of amenity as a result of excessive noise being transmitted between adjacent tenants or occupancies.</p>		
<p>[BG] 1003.2 Functional statement. Building elements that are common between tenants or occupancies shall be constructed to prevent excessive noise transmission from other tenants or occupancies or common spaces to habitable spaces.</p>		
<p>[BG] 1003.3 Performance requirements. [BG] 1003.3.1 Tenant separations. The airborne trans-mission of sound through tenant separation walls and floors shall be reduced to a level that minimizes its effect on adjacent occupants.</p>		
<p>[BG] 1003.3.2 Floors. The structure-borne transmission of sound through floors shall be reduced to a level that minimizes its effect on adjacent occupants.</p>		
<p style="text-align: center;">SECTION 1004 ARTIFICIAL AND NATURAL LIGHT</p> <p>[BG] 1004.1 Objective. To safeguard people from injury or loss of amenity due to lack of adequate lighting.</p>		
<p>[BG] 1004.2 Functional statements. [BG] 1004.2.1 Lighting for safe movement. Habitable spaces and means of egress within buildings shall be provided with adequate artificial lighting to enable safe movement.</p>		
<p>[BG] 1004.2.2 General lighting. Adequate natural or artificial light shall be provided in all habitable spaces.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BG] 1004.3 Performance requirements. [BG] 1004.3.1 Illumination. Adequate illumination shall be provided appropriate to the use and occupancy of the habitable spaces and means of egress served.</p>		
<p>[BG] 1004.3.2 Natural light. Natural light shall provide a luminance appropriate to the use and occupancy of the habitable spaces served.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 11 MECHANICAL	2021 Proposed	Code Analysis
<p align="center">SECTION 1101 HEATING, VENTILATION AND AIR-CONDITIONING EQUIPMENT (HVAC)</p>		
<p>[M] 1101.1 Objective. To provide the safe installation of the equipment to condition the air for the health and comfort of the occupants.</p>		
<p>[M] 1101.2 Functional statement. The installation of equipment shall safeguard maintenance personnel and building occupants from injury and deliver air at the appropriate temperature for health and comfort.</p>		
<p>[M] 1101.3 Performance requirements. [M] 1101.3.1 Protection from equipment. People and building elements shall be protected from contact with hot and live electrical parts.</p>		
<p>[M] 1101.3.2 Service and replacement ability. The HVAC system shall allow safe isolation and access for service and replacement of equipment.</p>		
<p>[M] 1101.3.3 Temperature controls. The HVAC system shall include devices to monitor and control the temperature.</p>		
<p>[M] 1101.3.4 Securing of equipment. HVAC equipment and appliances shall be secured in place.</p>		
<p align="center">SECTION 1102 REFRIGERATION</p> <p>[M] 1102.1 Objective. To provide the safe installation and operation of refrigeration equipment.</p>		
<p>[M] 1102.2 Functional statement. The installation of equipment shall safeguard maintenance personnel and building occupants from injury.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[M] 1102.3 Performance requirements. [M] 1102.3.1 Protection from equipment. People and building elements shall be protected from contact with hot or live electrical parts.</p>		
<p>[M] 1102.3.2 Service and replacement ability. Refrigeration equipment shall allow safe isolation and access for service and replacement of equipment.</p>		
<p>[M] 1102.3.3 Temperature controls. Refrigeration equipment shall include devices to monitor and control temperature.</p>		
<p>[M] 1102.3.4 Toxic and flammable refrigerants. Refrigeration equipment shall have appropriate safeguards where utilizing toxic or flammable refrigeration agents.</p>		
<p style="text-align: center;">SECTION 1103 PIPED SERVICES</p> <p>[M] 1103.1 Objective. To safeguard people from injury or illness caused by extreme temperatures or hazardous substances associated with building services.</p>		
<p>[M] 1103.2 Functional statement. In buildings with potentially hazardous services containing hot, cold, flammable, corrosive or toxic liquids or gases, the installations shall be constructed to provide adequate safety for people.</p>		
<p>[M] 1103.3 Performance requirements. [M] 1103.3.1 Construction. Piping systems shall be constructed to avoid the likelihood of:</p> <ol style="list-style-type: none"> 1. Significant leakage or damage during normal or reasonably foreseeable abnormal conditions. 2. Detrimental contamination of the contents by other substances. 3. Adverse interaction between services or between piping and electrical systems. 4. People having contact with pipes that could cause them harm. 		
<p>[M] 1103.3.2 Corrosion. Pipes shall be protected against corrosion in the environment of their use.</p>		
<p>[M] 1103.3.3 Identification. Piping systems shall be identified with markings if the contents are not readily apparent from the location or associated equipment.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

[M] 1103.3.4 Enclosed spaces. Enclosed spaces shall be constructed to avoid the likelihood of accumulating vented or leaking flammable gas.

[M] 1103.3.5 Isolation. A piped system shall have isolation devices that permit the complete system or components of the system to be isolated from the supply system for maintenance, testing, fault detection and repair.

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 12 PLUMBING	2021 Proposed	Code Analysis
<p align="center">SECTION 1201 PERSONAL HYGIENE</p> <p>[P] 1201.1 Objective. To provide facilities with appropriate space, fixtures and equipment for personal hygiene</p>		
<p>[P] 1201.2 Functional statement. To provide adequate plumbing fixtures that reasonably protect people from illness and provide reasonable access to such fixtures conducive to health, safety and comfort of the occupants.</p>		
<p>[P] 1201.3 Performance requirements. [P] 1201.3.1 Number of plumbing fixtures. Plumbing fixtures shall be provided in sufficient numbers appropriate for the intended use.</p>		
<p>[P] 1201.3.2 Privacy. Plumbing fixtures shall be located to provide appropriate privacy.</p>		
<p>[P] 1201.3.3 Cleanliness. Plumbing fixtures shall be constructed to avoid food contamination and accumulation of dirt or bacteria, and permit effective cleaning.</p>		
<p>[P] 1201.3.4 Wastewater removal. Plumbing fixtures shall be installed to discharge to drainage systems without contaminating food.</p>		
<p>[P] 1201.3.5 Location of plumbing fixtures. Facilities for personal hygiene shall be provided in convenient locations and spaces of appropriate size to permit the use of the fixtures.</p>		
<p align="center">SECTION 1202 LAUNDERING</p> <p>[P] 1202.1 Objective. To provide adequate facilities for laundry.</p>		
<p>[P] 1202.2 Functional statement. Laundry facilities shall be provided for use by occupants of dwelling units.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[P] 1202.3 Performance requirement. Space shall be adequate in size for the required fixtures and equipment.</p>		
<p style="text-align: center;">SECTION 1203 DOMESTIC WATER SUPPLIES</p> <p>[P] 1203.1 Objective. To provide sanitary distribution of water for drinking, food preparation and hygiene</p>		
<p>[P] 1203.2 Functional statement. Sanitary water shall be delivered to fixtures, appliances and equipment at temperatures appropriate for the intended use.</p>		
<p>[P] 1203.3 Performance requirements. [P] 1203.3.1 Potable water. Water supplies intended for human consumption, oral hygiene, food preparation and the washing of cooking equipment shall be potable.</p>		
<p>[P] 1203.3.2 Nonpotable water. Water supplies and outlets providing nonpotable water shall be clearly identified.</p>		
<p>[P] 1203.3.3 Hot water. Plumbing fixtures and appliances used for personal hygiene, laundering and the washing of cooking equipment shall be provided with hot water.</p>		
<p>[P] 1203.3.4 Scalding. Where hot water is provided for personal hygiene, it shall be delivered at a temperature to avoid scalding.</p>		
<p>[P] 1203.3.5 Water supply contamination. Water supplies shall be installed to avoid potable water contamination.</p>		
<p>[P] 1203.3.6 Flow rate and pressure. Water supplies shall be provided to plumbing fixtures, appliances and equipment at a flow rate and pressure adequate for their operation.</p>		
<p>[P] 1203.3.7 Leak prevention. Water piping shall be installed in a leak-free manner.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p>[P] 1203.3.8 Access. Water systems shall be installed to allow adequate access for maintenance.</p>		
<p>[P] 1203.3.9 Water piping isolation and protection from contamination. Water piping shall be installed with provisions for adequate isolation of the system and branches and to provide protection from contamination.</p>		
<p>[P] 1203.3.10 Hot water vessels. Vessels used for producing hot water shall be provided with safety devices to relieve excessive pressure and limit temperatures.</p>		
<p style="text-align: center;">SECTION 1204 WASTEWATER</p> <p>[P] 1204.1 Objective. To provide safe drainage and disposal systems for wastewater from plumbing fixtures, appliances and equipment.</p>		
<p>[P] 1204.2 Functional statement. The drainage system shall conduct wastewater to an appropriate disposal point, protect people from contamination and unpleasant odor, and avoid blockages.</p>		
<p>[P] 1204.3 Performance requirements. [P] 1204.3.1 Prevention of blockage and leakage. The drainage system shall conduct wastewater from all plumbing fixtures, appliances and equipment, avoiding the likelihood of blockage and leakage.</p>		
<p>[P] 1204.3.2 Sewer gases. The drainage system shall be designed and installed to prevent sewer gases from entering the building.</p>		
<p>[P] 1204.3.3 Accessibility. The drainage system shall be accessible for maintenance and clearing of blockages.</p>		
<p>[P] 1204.3.4 Sewer connection. The drainage system shall be connected to the sewer in a manner acceptable to the operator of the sewer system.</p>		
<p>[P] 1204.3.5 On-site sewage disposal. On-site sewage disposal systems shall be designed and installed in an approved manner.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

--	--	--

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 13 FUEL GAS	2021 Proposed	Code Analysis
<p>SECTION 1301 FUEL GAS PIPING AND VENTS</p> <p>[FG] 1301.1 Objective. To ensure that fuel gas is distributed and utilized in a safe manner.</p>		
<p>[FG] 1301.2 Functional statement. In buildings where fuel gas is used as an energy source, the vented and unvented gas piping systems shall be safe and adequate for their intended use.</p>		
<p>[FG] 1301.3 Performance requirements. [FG] 1301.3.1 General. Gas piping systems shall be free of leaks and operated at a safe pressure appropriate to the appliances served by the system.</p>		
<p>[FG] 1301.3.2 Isolation. Gas piping systems shall have isolation devices that permit isolation of appliances, or isolation of the gas piping systems from the supply, for maintenance, testing, leak detection or repair.</p>		
<p>[FG] 1301.3.3 Conveyance of products of combustion. Vented gas appliances shall convey products of combustion directly to the exterior without affecting the operation of other gas vents.</p>		
<p>[FG] 1301.3.4 Safety controls. Vented gas appliances shall be provided with safety controls that prevent their operation in the event of failure of forced ventilation systems or natural draft systems.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 14 ELECTRICITY	2021 Proposed	Code Analysis
<p>SECTION 1401 ELECTRICITY</p> <p>[BG] 1401.1 Objective. To provide safe installation of electrical power and lighting for building systems and safe use by building occupants.</p>		
<p>[BG] 1401.2 Functional statement. The electrical installations shall have safeguards against personal injury and the outbreak of fire.</p>		
<p>[BG] 1401.3 Performance requirements. [BG] 1401.3.1 Protection from live parts. People and building elements shall be protected against contact with live parts.</p>		
<p>[BG] 1401.3.2 Isolation. The electrical installation shall allow safe isolation of devices, equipment and appliances.</p>		
<p>[BG] 1401.3.3 Protection from excessive current. People shall be protected from the effects of current exceeding the rating of the installation.</p>		
<p>[BG] 1401.3.4 Electromechanical stress. The installation shall protect all components and equipment from electromechanical stress caused by current exceeding its rating.</p>		
<p>[BG] 1401.3.5 Thermal damage. Building elements shall be protected from thermal damage due to heat transfer or electric arc from electrical power installations.</p>		
<p>[BG] 1401.3.6 Installation environment. The installation shall operate safely in the intended environment.</p>		
<p>[BG] 1401.3.7 Flammable and explosive atmosphere. The installation shall prevent ignition of the atmosphere containing flammable or explosive elements.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

[BG] 1401.3.8 Essential services and equipment. Essential services and equipment shall have a power supply protected in a manner to ensure continued operation for an appropriate time after a power failure.

[BG] 1401.3.9 Power supplier. The building electrical installation shall protect the safety features of the power supplier.

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 15 ENERGY EFFICIENCY	2021 Proposed	Code Analysis
<p>SECTION 1501 ENERGY EFFICIENCY</p> <p>[CE] 1501.1 Objective. To facilitate efficient use of energy.</p>		
<p>[CE] 1501.2 Functional statement. Buildings shall have provisions ensuring efficient use of nonrenewable energy.</p>		
<p>[CE] 1501.3 Performance requirements.</p> <p>[CE] 1501.3.1 Energy performance indices. To provide for the efficient use of depletable energy sources, the building envelope shall be designed and constructed within stated parameters. These parameters are called the energy performance indices. These indices are the amount of energy from a depletable energy source passing through a specified building envelope area during a specified difference in internal and external temperature. These indices are based on the region of the country as well as the use of the building. Equivalent energy performance utilizing alternative energy conservation techniques is permitted. In some cases, for certain types of buildings, the local jurisdiction has the authority to choose not to specify energy performance indices.</p>		
<p>[CE] 1501.3.2 Temperature control. For buildings requiring a controlled temperature, the building design and construction shall take into account various factors. Normally, only insulation, types of windows and related building elements are considered when addressing energy conservation. However, to provide for the efficient use of energy, there are several other items that need to be taken into consideration, such as thermal resistance, solar radiation, air tightness and heat gain or loss from building services.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 16 FIRE PREVENTION	2021 Proposed	Code Analysis
<p align="center">SECTION 1601 FIRE PREVENTION</p> <p>[F] 1601.1 Objective. To limit or control the likelihood that a fire will start because of the design, operation or maintenance of a facility or its systems so as to minimize impacts on people, property, processes and the environment.</p>		
<p>[F] 1601.2 Functional statement. Facility services, systems and activities that represent a potential source of ignition or can contribute fuel to an incipient fire shall be designed, operated, managed and maintained to reduce the likelihood of a fire starting.</p>		
<p>[F] 1601.3 Performance requirements. [F] 1601.3.1 Ignition sources. Electrical, mechanical and chemical systems or processes and facility services capable of supplying sufficient heat under normal operating conditions or anticipated failure modes to ignite combustible system components, facility elements or nearby materials shall be designed, operated, managed and maintained to prevent the occurrence of fire.</p>		
<p>[F] 1601.3.2 Fuel sources. The quantities, configurations, characteristics or locations of combustible materials, including components or facility systems, facility elements, facility contents and accumulations of readily ignitable waste or debris shall be managed or maintained to prevent ignition by facility service equipment and other ignition sources associated with processes normally present or expected to be present within the facility.</p>		
<p>[F] 1601.3.3 Ignition and fuel source interactions. Design, operate, and maintain facility services and facility system installation locations to prevent the occurrence or to control the extent of atmospheres likely to pose an ignition hazard.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p style="text-align: center;">Chapter 17 FIRE IMPACT MANAGEMENT</p>	<p style="text-align: center;">2021 Proposed</p>	<p style="text-align: center;">Code Analysis</p>
<p style="text-align: center;">SECTION 1701 FIRE IMPACT MANAGEMENT</p> <p>[F] 1701.1 Objective. To provide an acceptable level of fire safety performance when facilities are subjected to fires occurring in the fire loads present in the facility during construction or alteration and throughout the intended life.</p>		
<p>[F] 1701.2 Functional statements. Facilities shall be designed with safeguards against the spread of fire so that persons not directly adjacent to or involved in the ignition of a fire shall not suffer serious injury or death from a fire, and so that the magnitude of the property loss is limited as follows: Performance Group I—High Performance Group II—Moderate Performance Group III—Mild Performance Group IV—Mild</p>		
<p>[F] 1701.2.1 Fire potential. Facilities and contents shall be maintained in a manner that limits the potential for fire.</p>		
<p>[F] 1701.2.2 Fire impact. Facilities shall be designed, constructed and maintained to limit the fire impact to people and property.</p>		
<p>[F] 1701.2.3 Time for evacuation. Facilities shall be designed, constructed, maintained and operated with appropriate safeguards in place to limit the spread of fire and products of combustion so that occupants have sufficient time to escape the fire.</p>		
<p>[F] 1701.2.4 Limitation on fire spread. Facilities shall be designed, constructed, maintained and operated in such a manner that the spread of fire through a building is restricted, and that fire does not spread to adjacent properties.</p>		
<p>[F] 1701.2.5 Wildland fires. In wildland interface areas, facilities and vegetation shall be designed, constructed, arranged and maintained in such a manner to limit the impact to the building and the facilities during a wildland fire event.</p>		
<p>[F] 1701.2.6 Emergency responder needs. Facilities shall be arranged, constructed, maintained and operated with appropriate safeguards in place to allow fire-fighting personnel to perform rescue operations and to protect property.</p>		
<p>[F] 1701.2.7 Structural integrity. Facilities shall be arranged, constructed and maintained so as to limit the impact of a fire on the structural integrity of the facility.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 1701.2.8 Capability of building or facility users. Facilities open to persons of varying physical and mental capabilities shall provide reasonably equivalent levels of fire safety protection for those persons to the levels it provides for persons without disabilities.</p>		
<p>[F] 1701.3 Performance requirements. Facilities or portions thereof shall be designed, constructed and operated to normally prevent any fire from growing to a stage that would cause life loss or serious injury, taking into account all anticipated and permitted fire loads that would affect their performance. Facilities shall be designed to sustain local fire damage, and the facility as a whole will remain intact and not be damaged to an extent disproportionate to the original local damage.</p>		
<p>[F] 1701.3.1 Interior surface finishes. Interior surface finishes on walls, floors, ceilings and suspended building elements shall resist the spread of fire and limit the generation of unacceptable levels of toxic gases, smoke and heat appropriate to the design performance level and associated hazards, risks and fire safety systems or features installed.</p>		
<p>[F] 1701.3.2 Building materials, processes and contents. Limit quantities, configurations and combustibility of building materials, processes and contents so that fire growth and size can be controlled.</p>		
<p>[F] 1701.3.3 Emergency responders. Where necessary, provide appropriate measures to limit fire and smoke spread and damage to acceptable levels so that fire fighters are not unduly hindered in suppression or rescue operations.</p>		
<p>[F] 1701.3.4 Detection and notification. Where human intervention or system or equipment response is necessary to limit the fire impact, provide appropriate means for detection and notification of fire.</p>		
<p>[F] 1701.3.5 Activation of detection systems. Fire detection systems, where provided, shall activate at a fire size appropriate to the fire and life safety strategies selected.</p>		
<p>[F] 1701.3.6 Activation of suppression systems. Automatic fire suppression systems, where provided as a means of controlling fire growth or to suppress the fire, shall deliver sufficient suppression agent to control or suppress the fire as appropriate.</p>		
<p>[F] 1701.3.7 Control of smoke. Smoke control systems, where provided, shall limit the unacceptable spread of smoke to nonfire areas as appropriate.</p>		
<p>[F] 1701.3.8 Concealed spaces. Construction in concealed spaces shall inhibit the unseen spread of fire and unacceptable movement of hot gases and smoke, appropriate to associated hazards, risks and fire safety systems or features installed.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 1701.3.9 Vertical openings. Vertical openings shall be constructed, arranged, limited or protected to limit fire and smoke spread as appropriate to the fire and life-safety strategies selected.</p>		
<p>[F] 1701.3.10 Wall, floor, roof and ceiling assemblies. Wall, floor, roof and ceiling assemblies forming compartments including their associated openings shall limit the spread of fire appropriate to the associated hazards, risks and fire-safety systems or features installed.</p>		
<p>[F] 1701.3.11 Structural members and assemblies. Structural members and assemblies shall have a fire resistance appropriate to their function, the fire load, the predicted fire intensity and duration, the fire hazard, the height and use of the building, the proximity to other properties or structures, and any fire protection features.</p>		
<p>[F] 1701.3.12 Exterior wall and roof assemblies' restriction of fire spread. Construction of exterior wall and roof assemblies shall restrict the spread of fire to or from adjacent buildings and from exterior fire sources, appropriate to the associated hazards, risks and fire safety systems or features installed.</p>		
<p>[F] 1701.3.13 Exterior wall and roof assemblies' contribution to fire growth. Construction of exterior wall and roof assemblies shall resist the spread of fire by limiting their contribution to fire growth and development, appropriate to the associated hazards, risks and fire safety systems or features installed.</p>		
<p>[F] 1701.3.14 Air handling and mechanical ventilation systems. Air handling and mechanical ventilation systems, where provided, shall be designed to avoid or limit the unacceptable spread of fire and smoke to nonfire areas as appropriate.</p>		
<p>[F] 1701.3.15 Magnitude of fire event. Design fire events shall realistically reflect the ignition, growth and spread potential of fires and fire effluents that could occur in the fire load that may be present in the facility by its design and operational controls.</p>		
<p>[F] 1701.3.15.1 Design fire events. Magnitudes of design fire events shall be described in terms of the potential spread of fire and fire effluents given the proposed design, arrangement, construction, furnishing and use of a building.</p>		
<p>[F] 1701.3.15.2 Range of fire sizes. Magnitudes of design fire events shall be defined as small, medium, large and very large, based on the quantification of the design fire event as a function of the building use and associated performance group.</p>		
<p>[F] 1701.3.15.3 Engineering analyses of potential fire scenarios. Quantification of the magnitudes of design fire events shall be based on engineering analyses of potential fire scenarios that can be expected to impact a building through its intended life. For each design fire scenario considered, the analyses shall include the ignitability of the first item, the peak heat release rate of the item first ignited, the rate</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>of heat release and expected fire growth, and the overall fuel load, geometry, and ventilation of the space and adjoining spaces.</p>		
<p>[F] 1701.3.15.3.1 Relationship of design fire to tolerable damage. When determining (assigning) the magnitude of a design fire event, the physical properties of the fire and its effluents shall only be considered in terms of how they impact the levels of tolerable damage. The magnitude of the fire event is not required to be characterized solely on the basis of the physical size of the fire in terms of its heat release and smoke production rates.</p>		
<p>[F] 1701.3.15.3.2 Design parameters. Multiple design fire scenarios, ranging from small to very large design fire events, shall be considered to ensure that associated levels of tolerable damage are not exceeded as appropriate to the performance group.</p>		
<p>[F] 1701.3.15.3.3 Factors in determining design fire scenarios. The development of design fire scenarios shall consider the use of the room of fire origin and adjoining spaces, in terms of impact on occupant, property and community welfare.</p>		
<p>[F] 1701.3.15.3.4 Justification. Justification of the magnitudes of design fire events and design fire scenarios shall be part of the analysis prepared by the registered design professional and shall take into consideration the reasonableness, frequency and severity of the design fire event and design fire scenarios.</p>		
<p>[F] 1701.3.15.3.5 Safety factors. Design fires and fire scenarios shall be chosen to provide appropriate factors of safety to provide adequate performance by accounting for the following factors:</p> <ol style="list-style-type: none"> 1. Effects of uncertainties arising from construction activities. 2. Variations in the properties of materials and the characteristics of the site. 3. Accuracy limitations inherent in the methods used to predict the fire safety of the building. 4. Variations in the conditions of facilities, systems, contents and occupants. 		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>Chapter 18 MANAGEMENT OF PEOPLE</p>	<p>2021 Proposed</p>	<p>Code Analysis</p>
<p>SECTION 1801 MANAGEMENT OF PEOPLE [F] 1801.1 Objective. To promote safe practices and actions of people, and to ensure that the actions and practices of people who are components of a design are maintained.</p>		
<p>[F] 1801.2 Functional statements. [F] 1801.2.1 Training and education for prevention of fires and other emergencies. Through training and education, ensure that people possess the necessary skills and implement the appropriate actions to prevent fires or other emergencies as appropriate to the design performance level determined in Chapter 3.</p>		
<p>[F] 1801.2.2 Training and education for mitigation of fires and other emergencies. Through training and education, ensure that people possess the necessary skills and implement the appropriate actions during a fire or other emergency as appropriate to the design performance level determined in Chapter 3.</p>		
<p>[F] 1801.3 Performance requirements. [F] 1801.3.1 Identification of hazards. Provide appropriate information so that occupants and staff can assist in identifying hazards.</p>		
<p>[F] 1801.3.2 Procedure development and training for fire or other emergency. Develop procedures and conduct training so that occupants and staff can take appropriate actions to prevent fires or other emergencies.</p>		
<p>[F] 1801.3.3 Actions during fires or other emergencies. Provide adequate information so that occupants and staff know the appropriate actions in the event of a fire or other emergency.</p>		
<p>[F] 1801.3.4 Procedure development and training for mitigation. Develop procedures and conduct training so that occupants and staff can take the appropriate actions in the event of a fire or other emergency.</p>		
<p>[F] 1801.3.5 Proper handling and use of hazardous materials. Provide adequate information so that all persons involved in the handling and use of hazardous materials know the appropriate actions and safeguards for such materials.</p>		
<p>[F] 1801.3.6 Hazardous materials emergency training. Develop procedures so that all persons involved in the handling and use of hazardous materials will take the appropriate actions in the event of an emergency.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 1801.3.7 Management of procedures and training. Provide the administrative controls to ensure that the identified hazards are controlled, procedures are followed and training occurs.</p>		
<p>[F] 1801.3.8 Validation of policies, procedures and training. Provide the administrative controls to evaluate and validate all policies, procedures and training for occupants and staff.</p>		
<p>[F] 1801.3.9 Management of change. Whenever new occupants, staff, equipment, materials or processes are introduced, the administrative controls shall provide for appropriate education and training.</p>		
<p>[F] 1801.3.10 Documentation of reliance on occupants and staff. Ensure that all aspects of a performance-based design that rely on a response or action from either occupants or staff are clearly identified and documented and that the necessary training and administrative controls are in place and maintained so that the response or action is appropriate.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

Chapter 19 MEANS OF EGRESS	2021 Proposed	Code Analysis
<p>SECTION 1901 MEANS OF EGRESS</p> <p>[BE] 1901.1 Objective. To protect people during egress and rescue operations.</p>		
<p>[BE] 1901.2 Functional statement. Enable occupants to exit the building, facility and premises or reach a safe place as appropriate to the design performance level determined in Chapter 3.</p>		
<p>[BE] 1901.3 Performance requirements. [BE] 1901.3.1 General. The construction, arrangement and number of means of egress, exits and safe places for buildings shall be appropriate to the travel distance, number of occupants, occupant characteristics, building height, and safety systems and features.</p>		
<p>[BE] 1901.3.2 Identification, illumination and safety of means of egress. Means of egress shall be clearly identified, provided with adequate illumination and be easy and safe to use.</p>		
<p>[BE] 1901.3.3 Unobstructed path. Means of egress shall provide an unobstructed path of travel from each safe place to not less than one exit.</p>		
<p>[BE] 1901.3.4 Protection from untenable conditions. Each safe place shall provide adequate protection from untenable conditions, an appropriate communication system and adequate space for the intended occupants.</p>		
<p>[BE] 1901.3.5 Human biomechanics and expectation of consistency. Means of egress shall enable reasonable use by the occupants in the building with due regard to human biomechanics and expectation of consistency.</p>		
<p>[BE] 1901.3.6 Maintenance of means-of-egress systems. Suitable means of egress shall be provided in satisfactory arrangement throughout all buildings, facilities and premises, regardless of when they were constructed, based on the number and character of occupants, length of travel, provision of existing alternative paths, timeline of emergency detection and response, risk level, time to exit and safety systems provided.</p>		
<p>[BE] 1901.3.7 Maintenance of clear path. Means of egress shall be maintained without obstructions or reductions in capacity that would hinder the ability of the occupants to egress safely.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[BE] 1901.3.8 Interference with identification of exits. Means of egress shall be readily identifiable. Buildings shall be operated and maintained in a manner that does not interfere with the identification of exits.</p>		
<p>[BE] 1901.3.9 Ease of use. Means of egress shall be maintained and operated in such a manner to ensure that all egress facilities are readily openable and available without special knowledge or effort consistent with the use or occupancy characteristics.</p>		
<p>[BE] 1901.3.10 Maintenance of illumination. Means of egress shall be maintained and operated in such a manner to ensure that adequate lighting to facilitate safe egress is available.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015
Yellow Strikethrough = Text Deleted from the Code by COH

Text Underlined = COH Amendment added (NEW)
Green Text = NEW or Modified Text by COH in 2015

Grey Text = Previous COH Amendment Brought Forward to 2015

<p style="text-align: center;">Chapter 20 EMERGENCY NOTIFICATION, ACCESS AND FACILITIES</p>	<p style="text-align: center;">2021 Proposed</p>	<p style="text-align: center;">Code Analysis</p>
<p style="text-align: center;">SECTION 2001 EMERGENCY NOTIFICATION, ACCESS AND FACILITIES</p> <p>[F] 2001.1 Objectives. [F] 2001.1.1 Notification, access and facilities for emergency responders. To provide and maintain means of notification, access and facilities for emergency operations and responders.</p>		
<p>[F] 2001.1.2 Notification for life safety and property protection. To provide notification of the need to take some manual action to preserve the safety of occupants or to limit property damage.</p>		
<p>[F] 2001.2 Functional statements. As appropriate to the design performance level in Chapter 3, the following shall be addressed:</p> <ol style="list-style-type: none"> 1. Provide and maintain appropriate access for emergency vehicles. 2. Provide and maintain appropriate access for emergency responders. 3. Provide and maintain necessary staging, command and control areas, support facilities and equipment for emergency operations. 4. Provide sufficient, reliable water for fire-fighting operations. 5. Provide and maintain appropriate means of promptly notifying emergency responders. 6. Where required, provide and maintain adequate means of occupant notification to warn of the presence of a fire or other emergency in sufficient time to enable occupants to take the contemplated action without being exposed to unreasonable risk of injury or death. 		
<p>[F] 2001.3 Performance requirements. [F] 2001.3.1 Vertical and horizontal clearance for fire department apparatus. Vertical and horizontal clearance shall permit the unimpeded access of fire department apparatus inclusive of the capability for one apparatus to pass another apparatus set up and in operation.</p>		
<p>[F] 2001.3.2 Protrusions and appurtenances from structures. Protrusions and appurtenances from structures shall not impede access, including vertical access, to the height of fire department aerial apparatus.</p>		
<p>[F] 2001.3.3 Surfaces for fire department apparatus. Fire department access shall be on surfaces permitting year-round, all-weather travel at a grade appropriate for the fire apparatus.</p>		
<p>[F] 2001.3.4 Hose length limitations. Access to structures shall afford the fire department the ability to deploy and operate hose lines without the need to extend the standard hose line utilized by the fire department having jurisdiction.</p>		
<p>[F] 2001.3.5 Control valve locations. Within structures, means for the deployment and operation of hose lines by emergency responders shall be provided such that control valves for lines shall be no further from potential fire sources than the length of hose packs employed by a single engine company of the fire department having jurisdiction.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 2001.3.6 Water supply. Water supply for fire department operations shall be from a reliable, readily accessible source acceptable to the fire department and capable of supporting fire-fighting operations.</p>		
<p>[F] 2001.3.7 Horizontal or vertical conveyance. Means of horizontal or vertical conveyance shall be provided where necessary to support fire-fighting and emergency support functions.</p>		
<p>[F] 2001.3.8 Staging areas. Where interior operations may be necessary, areas to stage equipment and from which to safely conduct and to control suppression operations shall be provided.</p>		
<p>[F] 2001.3.9 Interaction of access and means of egress. Exterior and interior egress and emergency access shall be arranged and maintained so that building occupants and emergency responders are unimpeded as each accomplishes its objectives of egress of occupants and access by emergency responders.</p>		
<p>[F] 2001.3.10 Interior and exterior staging. Where necessary to ensure timely and effective emergency operations, interior or exterior areas shall be provided for the staging of equipment and apparatus.</p>		
<p>[F] 2001.3.11 On-site equipment. Where necessary to ensure timely and effective emergency operations, fire-fighting equipment or other equipment to support such operations shall be provided and maintained readily available for use by emergency responders.</p>		
<p>[F] 2001.3.12 Notification requirements. Where systems are designed to notify the emergency-response agency of the need to respond to an emergency, such system shall indicate the type of emergency and the location of the building, premises or facility. Where such buildings, premises or facilities are large enough that difficulty is expected in promptly locating the emergency, identification of the area or zone of the emergency shall be provided at the building, premises or facilities.</p>		
<p>[F] 2001.3.13 Notification of occupants. Notification of occupants shall be by means appropriate to the needs of the occupants, the use of the building and the emergency egress strategy employed.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 21 EMERGENCY RESPONDER SAFETY	2021 Proposed	Code Analysis
<p align="center">SECTION 2101 EMERGENCY RESPONDER SAFETY</p> <p>[F] 2101.1 Objective. To protect emergency responders from unreasonable risks during emergencies.</p>		
<p>[F] 2101.2 Functional statements. As appropriate to the design performance level determined in Chapter 3, the following shall be provided:</p> <ol style="list-style-type: none"> 1. Information to responders regarding hazards present at the building or premises. 2. Protection against unanticipated structural collapse. 3. Appropriate fire service communications capability. 		
<p>[F] 2101.3 Performance requirements. [F] 2101.3.1 Identification of hazards. Where hazards are present in the building, facility or premises that could endanger emergency responders beyond what would normally be anticipated, means shall be provided to alert the responders to the hazards.</p>		
<p>[F] 2101.3.2 Signage. Signage shall be provided as needed to identify special hazards to the emergency responders (and to the degree applicable, the nature of the hazard).</p>		
<p>[F] 2101.3.3 Collapse. Buildings and structures shall be designed, constructed, loaded and maintained so that the potential for structural collapse is predictable based on the construction method, building condition and fire size, location and duration.</p>		
<p>[F] 2101.3.4 Communication systems. Communication systems for use by the emergency responders must be provided where the size, construction or complexity of the building cause the emergency responders' communication methods to be ineffective or unreliable.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX: **Turquoise** = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

Chapter 22 HAZARDOUS MATERIALS	2021 Proposed	Code Analysis
<p align="center">SECTION 2201 HAZARDOUS MATERIALS</p> <p>[F] 2201.1 Objective. To protect people and property from the consequences of unauthorized discharge, fires or explosions involving hazardous materials.</p>		
<p>[F] 2201.2 Functional statements. [F] 2201.2.1 Prevention. Provide adequate safeguards to minimize the risk of unwanted releases, fires or explosions involving hazardous materials as appropriate to the design performance level determined in Chapter 3.</p>		
<p>[F] 2201.2.2 Mitigation. Provide adequate safeguards to minimize the consequences of an unsafe condition involving hazardous materials during normal operations and in the event of an abnormal condition in accordance with the design performance level determined in Chapter 3.</p>		
<p>[F] 2201.3 Performance requirements. [F] 2201.3.1 Properties of hazardous materials. The properties of hazardous materials on site shall be known and shall be available to employees, neighbors and code enforcement officials.</p>		
<p>[F] 2201.3.2 Reliability of equipment and operations. Equipment and operations involving hazardous materials shall be designed, installed and maintained to ensure that they reliably operate as intended.</p>		
<p>[F] 2201.3.3 Prevention of unintentional reaction or release. Adequate safeguards shall be provided to minimize the risk of an unintentional reaction or release that could endanger people or property.</p>		
<p>[F] 2201.3.4 Spill mitigation. Spill containment systems or means to render a spill harmless to people or property shall be provided where a spill is determined to be a plausible event and where such an event would endanger people or property not in the immediate area of the spill.</p>		
<p>[F] 2201.3.5 Ignition hazards. Adequate safeguards shall be provided to minimize the risk of exposing combustible hazardous materials to unintended sources of ignition.</p>		
<p>[F] 2201.3.6 Protection of hazardous materials. Adequate safeguards shall be provided to minimize the risk of exposing hazardous materials to a fire or physical damage whereby such exposure could endanger or lead to the endangerment of people or property.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 2201.3.7 Exposure hazards. Adequate safeguards shall be provided to minimize the risk of and limit damage from a fire or explosion involving explosive hazardous materials whereby such fire or explosion could endanger or lead to the endangerment of people or property.</p>		
<p>[F] 2201.3.8 Detection of gas or vapor release. Where a release of hazardous materials gas or vapor would cause immediate harm to persons or property and where such materials would not be detectable at the danger threshold by sight or smell, an adequate means of detecting, diluting or otherwise mitigating the dangerous effects of a release shall be provided.</p>		
<p>[F] 2201.3.9 Reliable power source. Where a power supply is relied on to prevent or control an emergency condition that could endanger people or property, the power supply shall be from a reliable source.</p>		
<p>[F] 2201.3.10 Ventilation. Where ventilation is necessary to limit the risk of creating an emergency condition resulting from normal or abnormal operations, an adequate means of ventilation shall be provided.</p>		
<p>[F] 2201.3.11 Process hazard analyses. Process hazard analyses shall be conducted as necessary to reasonably ensure protection of people and property from dangerous conditions involving hazardous materials.</p>		
<p>[F] 2201.3.12 Written procedures and enforcement for prestartup safety review. Written documentation of prestartup safety review procedures shall be developed and enforced to ensure that operations are initiated in a safe manner. The process of developing and updating such procedures shall involve participation of affected employees.</p>		
<p>[F] 2201.3.13 Written procedures and enforcement for operation and emergency shutdown. Written documentation of operating procedures and procedures for emergency shutdown shall be developed and enforced to ensure that operations are conducted in a safe manner. The process of developing and updating such procedures shall involve participation of affected employees.</p>		
<p>[F] 2201.3.14 Written procedures and enforcement for management of change. A written plan for management of change shall be developed and enforced. The process of developing and updating the plan shall involve participation of affected employees.</p>		
<p>[F] 2201.3.15 Written procedures for action in the event of emergency. A written emergency response plan shall be developed to ensure that proper actions are taken in the event of an emergency, and the plan shall be followed if an emergency condition occurs. The process of developing and updating the plan shall involve participation of affected employees.</p>		
<p>[F] 2201.3.16 Written procedures for investigation and documentation of accidents. Written procedures for investigation and documentation of accidents shall be developed, and accidents shall be investigated and documented in accordance with these procedures.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

Yellow Strikethrough = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

<p>[F] 2201.3.17 Consequence analysis. Where an accidental release of hazardous materials could endanger people or property off site, an analysis of the expected consequences of a plausible release shall be performed and utilized in the analysis and selection of active and passive hazard mitigation controls.</p>		
<p>[F] 2201.3.18 Safety audits. Safety audits shall be conducted on a periodic basis to verify compliance with the requirements of this chapter.</p>		
<p>[F] 2201.3.19 Levels of impact. Levels of impact related to injuries to persons, damage to processes, structure, contents and to the environment shall comply with the requirements of Section 304 for design performance levels.</p>		
<p>[F] 2201.3.19.1 General. Magnitudes of design events shall reflect the ignition, spill or release, growth and spread potential of hazardous materials that can be reasonably expected to impact buildings and facilities as designed or constructed.</p>		
<p>[F] 2201.3.19.2 Design hazardous materials release or reaction events. Magnitudes of design events are described in terms of the potential effects given the proposed design, arrangement, construction, furnishing and use of a building or facility.</p>		
<p>[F] 2201.3.19.3 Range of event sizes. Magnitudes of design events shall be defined as small, medium, large and very large, where the quantification of the design event is a function of building or facility use and associated performance group.</p>		
<p>[F] 2201.3.19.4 Engineering analysis of potential event scenarios. Quantification of the magnitudes of design events shall be based on engineering analyses of potential scenarios that can be expected to impact a building or facility through its intended life. For each design scenario considered, the analyses shall include the ignitability, reactivity, spill or release potential, the peak release rate, the rate of continued release and expected incident growth, the overall quantity, the toxicity, chemical state and other specific hazards of the material and its impacts on people and property. The physical characteristics and ventilation of the space or area and adjoining spaces or areas shall be considered.</p>		
<p>[F] 2201.3.19.5 Design parameters. Multiple scenarios, ranging from small to very large design events, must be considered to ensure that associated levels of tolerable damage are not exceeded as appropriate to the performance group.</p>		
<p>[F] 2201.3.19.6 Factors in determining design events scenarios. The use of the room or area of event and adjoining spaces, in terms of occupant risk, property protection and community welfare (importance) factors, shall be considered in the development of design scenarios.</p>		

2021 Code Changes

2021 Houston Proposed

Code Change Summary

COLOR CODE INDEX:

Turquoise = NEW or Modified Text by ICC in 2015

Text Underlined = COH Amendment added (NEW)

Grey Text = Previous COH Amendment Brought Forward to 2015

~~Yellow Strikethrough~~ = Text Deleted from the Code by COH

Green Text = NEW or Modified Text by COH in 2015

[F] 2201.3.19.7 Justification. Justification of the magnitudes of design events shall be part of the analysis prepared by the registered design professional.